





# THE IMPACT OF HIGH RES ON POSSIBLE GRID CONSTRAINTS IN THE BLACK SEA REGION Final Report

Black Sea Transmission Planning Project (BSTP) Sub-Agreement: USEA/USAID - 2020 - 708 - 01

Monday, October 19, 2020

This report made possible by the support of the American people through the United States Agency for International Development (USAID). The contents are the responsibility of the United States Energy Association and do not necessarily reflect the views of USAID or the United States Government.







## THE IMPACT OF HIGH RES ON POSSIBLE GRID CONSTRAINTS IN THE BLACK SEA REGION

## Final Report

Black Sea Transmission Planning Project (BSTP)

Prepared for:

United States Agency for International Development and United States Energy Association

Sub-Agreement: USEA/USAID - 2020 - 708 - 01

Authors:

Dragana Orlić, Electricity Coordinating Center (EKC) Bogdan Lutovac, Electricity Coordinating Center (EKC) Branko Leković, Electricity Coordinating Center (EKC) Matija Kostić, Electricity Coordinating Center (EKC) Boris Brdjanin, Electricity Coordinating Center (EKC)

> United States Energy Association 1300 Pennsylvania Avenue, NW Suite 550, Mailbox 142 Washington, DC 20004 +1 202 312-1230 (USA)

This report is made possible by the support of the American people through the United States Agency for International Development (USAID). The contents are the responsibility of the United States Energy Association and do not necessarily reflect the views of USAID or the United States Government.



# **CONTENTS**

COI		۲S	2				
Abb	Abbreviations						
I.	Exec	utive summary	5				
II.	INTR	ODUCTION	8				
	II.1	Organization of the Report	9				
III.	PRO	POSED METHODOLOGICAL APPROACH AND SCENARIOS	10				
	III.1	Methodological Approach	10				
	III.2	Proposed Scenarios	12				
IV.	MAR	KET: MODELING, ANALYSES AND RESULTS	16				
	IV.1	Input data and modeling approach	16				
	IV.2	Summary of the input data for all countries	23				
	IV.3	Results of the market simulations	27				
	IV.4	Regional Summary	45				
V.	NET\	NORK: MODELING, ANALYSES AND RESULTS	49				
	V.1	System Modeling for Grid Analyses	49				
	V.2	Selection of the hours that corresponds to specific regimes	50				
	V.3	Results of the network analyses	52				
	V.4	Regional Summary	73				
VI.	Conc	lusions	75				
VII.	VII. REFERENCES						
Tab	Table of Figures 82						
Tab	Table of Tables						



# ABBREVIATIONS

#### General

tso Ucte	- Transmission System Operator - Union for the Coordination of Transmission of Electricity
ENTSO/E	- European Network of Transmission System Operators for Electricity (former UCTE)
ACER	- Agency for the Cooperation of Energy Regulators
REM	- Regional Energy Market
SEE	- South East European
BSTP	- Black Sea Transmission Project
BSRI	- Black Sea Regulatory Initiative
USEA	- United States Energy Association
NARUC	- National Association of Regulatory Utility Commissioners
PSS/E	- Power System Simulator for Engineering
OPF	- Optimal power flow
IPS/UPS	- Interregional Power System/Unified Power System

#### Transmission

- AC Alternating Current
- DC Direct Current
- HV High Voltage
- MV Medium Voltage
- LV Low Voltage
- HVAC High Voltage AC
- HVDC High Voltage DC
- NTC Net Transfer Capacity
- TTC Total Transfer

#### Generation

- HPP Hydro Power Plant
- PHPP Pumping Hydro Power Plant
- TPP Thermal Power Plant
- NPP Nuclear Power Plant
- CCGT Combined cycle gas turbine
- CHP Combined Heat and Power Generation
- RES Renewable Energy Sources
- MOR Maintenance Outage Rate
- FOR Forced Outage Rate

#### Adequacy

ENS - Energy Not Supplied

LOLE Loss of Load Expectations, number of hours during the year in which supply is below the load



LOLP	- Loss c	of Load	Probability
	<b>—</b> ·	~	

- PC Primary Control
- SoS Security of Supply

#### **Balancing Market**

LFCR - Load-Frequency Control

#### Countries

	ISO	Country	Car
Bulgaria	BG	BUL	BG
Romania	RO	ROM	ROM
Turkey	TR	TUR	TUR
Ukraine	UA	UKR	UKR
Armenia	AM	ARM	ARM
Georgia	GE	GEO	GEO
Moldova	MD	MLD	MLD
Russia	RU	RUS	RUS
Azerbaijan	AZ	AZB	AZB
Belorussia	BY	BLR	BLR
Poland	PL	PL	PL
Slovakia	SK	SK	SK
Hungary	HU	HU	HU
Serbia	RS	RS	RS
North Macedon	ia MK	MK	MK
SEE Sou	ith Easy Eui	rope	
EE	East Europ	e	



# I. EXECUTIVE SUMMARY

As RES integration is recognized as one of the highest priorities for TSOs in the long-term, the Black Sea Transmission Planning Project (BSTP) conducted analyses that investigate the impact of largescale RES integration on market and network operations.

The main motivation for conducting this kind of analysis can be found in the sheer size of the envisaged growth of RES capacities until 2030 (see Figure 1) and correlated market and network challenges.



Figure 1: Envisaged growth of installed RES capacities and their share in the BSTP region

Namely, in the entire BSTP region, RES capacities will grow from 22 GW in 2018 to 62 GW in 2030, which is almost triple in just 12 years. RES share in total installed capacities will grow to around 25%-35% for the majority of BSTP countries, except Georgia, which beside wind and solar power plants have ambitious plans for the development of HPPs.

The large-scale exploitation of renewable energy sources will pose challenges for electricity system operations, requiring higher levels of back-up capacity and additional sources of flexibility. Market designs that are primarily based on short-run marginal costs (SRMC) or energy costs, may fail to deliver the necessary level of flexibility in the long term, affecting the availability of back-up capacity and ancillary services. Having this in mind, the objectives of the study were to analyze and quantify the impact of large-scale RES integration in the Black Sea region on both electricity networks and electricity market operations.

Market analysis was conducted by developing a regional Market model in Antares on a plant-byplant level and running the annual Monte Carlo simulation on the hourly resolution. Network analysis was conducted by developing a regional Network model in PSS/E sw tool and running simulations for most critical regimes regarding the impact of high RES integration. The study was conducted for two scenarios: Referent RES and High RES, where referent RES represents official expected plans for RES integration, provided by BSTP members, and high RES represents sensitivity analysis for even higher RES integration.



The market analysis showed the impact of large-scale RES integration on wholesale market prices, the energy mix and CO2 emissions, country balances and cross-border energy exchanges. The network analysis showed the impact of large-scale RES integration on load flows, voltage profiles and secure grid operations.

Key findings and policy implications that can be taken from these analyses are the following:

- Generation adequacy and security of supply are maintained in each BSTP member state in both referent and high RES integration scenarios.
- Higher RES generation provokes a reduction of generation from fossil-fired TPPs with equal share between gas and lignite/coal technologies. This is followed by wholesale market prices reduction and issues related to reduced profitability may be expected for both technologies.
- Higher RES generation enables a decrease of CO2 emission, from 139.2 mil.T to 130.7 mil.T (-6%).
- Required balancing reserve can be provided in all hours during the year in all analyzed climatic years and hydrological conditions in almost all BSTP countries except:
  - In the case of Georgia, where required balancing reserve of 390 MW cannot be satisfied in around 60 hours per year but only during flooding season.
  - In the case of Romania, where required balancing reserve of 1400 MW cannot be satisfied in around 240 hours per year, in all seasons except in spring.
- In Armenia and Georgia higher RES generation leads to increased RES curtailment or increased spillages which in Georgia (where drastic HPPs generation increase is expected) reach 3.3 TWh or 14% of total Georgia demand! Having this in mind further investigations related to acceptable levels of RES capacities and the introduction of flexibility levers are advised. Also, a big decrease in wholesale market prices may seriously endanger the business environment for the thermal plants in both countries.
- In the case of Ukraine and Turkey, high RES integration and prices decrease could have a positive impact on the wholesale market and energy trade. However, maybe more interesting are expected changes in these power systems from today till 2030:
  - In the case of Ukraine, large-scale decommissioning of coal TPPs is envisaged till 2030 which will drastically change the generation mix and balance will be changed from +5 TWh (export) in 2017 to -19 TWh and -11 TWh (import) in referent and high RES scenarios, respectively.
  - In the case of Turkey, expected consumption growth (from 300 TWh to 412 TWh) will be hardly compensated with new HPPs, nuclear plants and a rather high level of RES: +48 TWh in referent and + 56 TWh in high RES scenario. So, Turkish import will increase from 2.7 TWh (2018) to 24 TWh.
- Analyses of the wholesale market prices show that in 2030 BSTP countries are grouped in 3 price zones:
  - Armenia and Georgia (around 25-35\$/MWh); Armenia and Georgia have lower prices than the central part of the BSTP region due to cheaper gas (and non-CO2 taxes) and excess of HPPs and RES generation
  - Bulgaria, Moldova, Romania and Ukraine (around 55\$/MWh-60\$/MWh) and



- Turkey (around 70 \$/MWh), since it is a big importing market zone.
- Testing of the network operation in the high RES scenario showed that high RES integration in the Black Sea Region causes some but not significant issues in the transmission network. In several cases, security violations that already exist in the high voltage network in the referent RES scenario are resolved by the integration of more RES capacities at lower voltage levels and by relieving the loading of elements caused by the conventional flow of power from higher towards lower voltage levels.
- In just a few cases, security violations have been observed at internal lines (220 or 400 kV in Romania and Turkey) usually highly loaded, mostly due to the high generation from power plants. When there are problems with the evacuation of the generation, causing issues in the system, it is recommended to direct the generation towards a higher voltage level (400 kV). This improves security conditions and reduces losses in the system. In some cases, the solution could be proper topological changes, or, in other cases, the upgrade of existing substations to higher voltage levels is recommended.
- In order to improve network flexibility and reliability, national Grid Codes should define all relevant requirements that newly connected RES power generating units should fulfill. This includes the provision of ancillary services such as balancing and frequency regulation, as well as voltage and reactive power regulation which improves security and enables flexibility in achieving optimum network operation.

Further, more detailed conclusions can be found in chapter VI.



# **II. INTRODUCTION**

The large-scale exploitation of renewable energy sources poses challenges for electricity system operations, requiring higher levels of back-up capacity and additional sources of flexibility. Currently, market designs are primarily based on short-run marginal costs (SRMC) or energy costs. There is a risk the SRMC may fail to deliver the necessary level of flexibility in the long term, affecting the availability of back-up capacity and ancillary services. Conventional power plants (considered the main resources of flexibility) must run at lower hours, resulting in reduced profitability while they are exposed to more changeable and variable load operating conditions. These situations trigger the need for the implementation of alternate mechanisms (e.g. capacity mechanism) necessary for the provision of the required security of supply.

Adding large-scale RES to transmission networks may increase the possibility of overloading network elements and forming bottlenecks in the High Voltage (HV) transmission networks. These conditions present difficulties, as they may require Transmission System Operators (TSO) to increase system operation costs.

As RES integration is recognized as one of the highest priorities for TSOs in the long-term, the Black Sea Transmission Planning Project (BSTP) conducted analyses that investigates the impact of large scale RES integration on market and network operations.

The objectives of the study are to analyze and quantify the impact of large-scale RES integration in the Black Sea region on both electricity networks and electricity market operations.

The results of this Study provides the following benefits for the BSTP members:

- 1. Optimizing regional generation
- 2. Improving utilization of the internal and cross-border grids
- 3. Anticipating needed network and interconnection investments
- 4. Recognition of the RES impact on the wholesale power prices and conventional generation
- 5. Showcasing the potential for considerably lower emissions
- 6. Eliminating seams and increasing resilience

The Study analyzed the impact of high RES development on electricity markets and prices and how the transmission grid will need to adapt – both internally within the BSTP member countries and between them - to successfully integrate these resources with a two phased approach:

- 1) An assessment of the changes in the regional electricity market, as they add a rapidly growing share of RES; and
- 2) An assessment of the network impacts of RES development, including where congestion may arise and where new transmission network elements may be required.

The market analysis carried out hourly simulations of the power system and provides results for each hour of the year. The network forecast focuses on snapshots of the grid operations at moments



when the networks could be under stress. The analyses were conducted for the forecasted target year 2030.

The market analysis enables the BSTP members to assess and understand the impact of large-scale RES integration on wholesale market prices, the energy mix, country balances, cross-border energy exchanges,  $CO_2$  emissions and congestion costs.

The network analysis enables the BSTP members to better understand the effects of large-scale RES integration impact on load flows, voltage profiles, secure grid operations and congestion in the regional transmission network.

Upon completion of the Study, the network and market models (in Antares and PSS/E forms) will be transferred to the BSTP members.

## **II.1 Organization of the Report**

This Final Report (FR) consists of five chapters:

Chapter 2: Introduction

Chapter 3: Proposed methodological approach and scenarios

Chapter 4: Market: Modeling, Analyses and Results

Chapter 5: Network: Modeling. Analyses and Results

Chapter 6: Conclusions

Chapter 7: List of References

Review of the market input data sets and review of the initial network models are given in Appendices.



# III. PROPOSED METHODOLOGICAL APPROACH AND SCENARIOS

This Chapter presents the summary of the applied methodology and description of the analysed Scenarios. More information can be found in Interim Report.

This study methodology builds upon previous BSTP Studies and the agreed scope related to the impact of large scale RES.

## III.1 Methodological Approach

The methodology is divided into two sections:

- 1. Market Analysis
- 2. Network Simulations

The electricity market simulations for the future time horizon include seven main drivers:

- 1. Electricity demand level
- 2. Hydrological conditions
- 3. RES generation capacities
- 4. Non-RES (conventional generation) generation capacities
- 5. Fuel prices (gas, coal)
- 6. CO<sub>2</sub> emission prices
- 7. Available transmission interconnection capacities

These drivers are not fully independent, but rather mutually related.

The primary focus of this Study is the analysis of the integration of large-scale RES and its impact on the electricity markets and network operations in the Black Sea region. Therefore, the Study focuses on RES generation capacities while other influential drivers are kept at a constant in all analyzed scenarios (when applying the expected, referent values).

For each BSTP member country, two levels of large-scale RES are modelled and analyzed:

- referent RES capacities
- high RES capacities

The referent level of RES integration value is sourced from BSTP member documents, such as the transmission network development plans or national energy strategy of national energy and climate plans (NCEP). Furthermore, the RES projects are formally verified by the BSTP members through grid connection agreements, connection consents, or connection requests.



The High-RES scenario is defined as large-scale RES integration, including RES projects that are under development or under potential evaluation but are not yet formally approved or registered by the TSO. As each BSTP member approaches actual and planned RES projects differently, the Consultant added variant RES inputs based on location, size and total installed capacity for the ten year timeframe analyzed in this study.

A breakdown of the methodology is shown in the following figure:





The modeling included two phases for the 2030 planning horizon:

- Creation of the regional BSTP market model in the Antares Software Tool, encompassing relevant parts of the "outside" markets (Europe, Central Asia, IPS/UPS);
- Merging of the individual network models into a regional network model, including expected system generation patterns, load changes and network topology.

The market simulations ran on an hourly basis, providing 8760 hourly results and the impact of variant RES levels on the the following indicators:

- Impact on market prices: wholesale day-ahead market prices for the region as well as on the country level
- Impact on the generation mix: changes in the electricity generation mix by country and the region for time horizon 2030
- Impact on carbon emissions: changes in thermal generation and total carbon emissions



• Impact on commercial exchanges: level of imports and exports at the country and regional level

After the market simulations were complete, the Consultant selected characteristic market results and transited them to the network model (step 4). Among a series of 8760 market simulation results, several of the most indicative snapshots from the network operation perspective (network element loading, voltage profiles or system security) were selected and transferred to the network simulation software PSS/E. The characteristic market results were selected based on the scenarios as described in the following subchapter.

In the network analyses, the following four outputs have been obtained:

- 1. Load flows in the transmission networks;
- 2. Voltage profiles on all transmission network nodes;
- 3. Transmission network losses per country and on the regional level;
- 4. Security analyses (N-1) and detection of the network bottlenecks.

After completion of the five step approach, the developed market and network models will be transferred to the BSTP members and an advanced training course on the Antares software application will be conducted by the Consultant.

## **III.2 Proposed Scenarios**

To analyze and quantify the impact of large-scale RES integration on regional electricity markets, the Consultant analysed the target level of RES penetration (referent RES case) and the higher RES integration scenario (e.g. 25% higher than the referent one) for each member country. Utilizing the Monte Carlo approach in the Antares Software Platform, the system operations were simulated in several Monte Carlo years by combining different climatic conditions, hydrology and random distribution of thermal power plant unavailability. Monte Carlo "years" (30) were developed as a combination of 10 climatic years (related to climatic years 2006-2015), 3 hydrological conditions (average, dry, wet) and random availability of thermal units.

The analysed market scenarios are presented in Figure 3:





Figure 3: Market scenarios analysed in the Study

The Antares Model tested the changes in market prices, cross-border flows, generation mix, CO2 emissions and other factors associated with substantial growth in RES deployment by target year 2030. The hourly dispatch results obtained as market model simulations (Figure 4) served as input for network simulations of operational regimes of interest.





In addition to the market scenarios, the network analysis scenarios were developed to assess the impact of large-scale RES on the transmission network operations in different regimes. The network scenarios were developed using three main criteria: 1) Base cases; 2) Load/RES level; and 3) Network availability (all (n) elements available and n-1 elements available).

As shown in the following chart, two groups of network scenarios have been analyzed: 1) Referent level of RES integration; 2) High RES integration scenario that is 25% higher than the referent or determined by the BSTP members.





### Network scenarios (12)

Figure 5: Network regimes analysed in the Study

For each scenario, three regimes were analyzed:

- 1) **Max load regime:** Winter maximum load regime model + load and generation dispatch taken from market simulation results for third Wednesday in January 2030 at 18:00 CET
- 2) Max WPP+SPP regime: Summer maximum load regime model + load and generation dispatch taken from market simulation results for the hour in which maximum of the sum of wind and solar generation is realized
- 3) **Max SPP regime:** Summer maximum load regime model + load and generation dispatch taken from market simulation results for the hour in which maximum of the solar generation is realized

The Consultant ran contingency analyses, with: 1) all network elements available (n), (2) one key element out of operation (n-1).

The number of scenarios is higher for the network analyses than for the market analyses as the network analyses includes an additional set of scenarios related to network element availability. One set of network scenarios is made under the assumption of full availability of



all network elements, while the other one is analyzed with one-by-one network elements unavailable (so called n-1 security criterion). These scenarios are based on all network codes the transmission network must employ to operate without any limitation in case one element is unavailable. In other words, an outage or the maintenance of any single network element should not cause any problem in transmission network operations.

These scenarios provided a wide range of network conditions based on RES and load levels, generation output and network availability. As the inputs are uncertain, this approach identifies many if not all potential bottlenecks in the network for target year 2030, regardless of their probability.

In all analyzed scenarios with referent and high RES penetration, certain assumptions are the same, including: existing and planned conventional generation capacities in the region with detailed technical and economic inputs, CO2 taxes and fuel prices, cross-border transmission capacities and prices on external electricity markets. The impact of variable climatic conditions that refer to load and RES generation, impact of variable hydrological conditions as well as availability of thermal units are analyzed through the Monte Carlo market simulation approach. For detailed network simulations, the selection of the relevant regimes also encompassed the selection of the climatic year.



# IV. MARKET: MODELING, ANALYSES AND RESULTS

## IV.1 Input data and modeling approach

The development of the BSTP market modeling database has been comprised of the following:

- ✓ Definition of the relevant input data needed for the market analyses on the regional level in the selected software tool – Antares<sup>1</sup>
- ✓ Collection of input data for target year 2030 from the BSTP member TSOs through a comprehensive spreadsheet
- Clarification of any missing input data and suggestions for solutions, including sources such as TYNDP, MAF and other publicly available sources, as well as the Consultants' databases

The Study employed the following approach to model the BSTP power systems and neighboring areas:

- The Armenian, Bulgarian, Georgian, Moldovan, Romanian and Ukrainian power systems have been represented on a plant-by-plant level, with demand and non-dispatchable generation modeled on an hourly level.
- The Turkish power system has been modeled by technology clusters (hydro by type, thermal by fuel type, nuclear, RES), with demand and non-dispatchable generation modeled at an hourly level. The Turkish data has been provided by Turkish TSO after Interim Report was finalized and they are presented in the Appendix of this Report.
- The neighboring power systems in EE and SEE have been modeled with different levels of detail (per plant or per technology), while distant zones (CE Germany & Austria) modeled as spot markets (in which the market price is insensitive to fluctuations of prices in the Black Sea region) and constrained by cross-border transmission capacity (see chapter 1.5).
- Commercial exchanges with the IPS/UPS and Belarussian systems have not been simulated.

<sup>&</sup>lt;sup>1</sup> Antares – probabilistic software tool for simulation of power system operation based on day-ahead market principles, developed by RTE (French TSO).



• Central Asia has been included in the model, as envisaged export under the "gas-forelectricity" agreement (1,218 GWh at annual level).

The following are the technical and economic parameters included in the 2030 market model:

1. Thermal Power Plants (TPPs)

- General data (plant name, number of units, fuel type)
- Operational status for each unit for target year 2030
- Maximum net output power per unit
- Minimum net output power per unit
- Heat rates at maximum net output power per unit
- Fuel costs per unit
- Variable O&M costs per unit
- · Outage rates (FOR, MOR) and maintenance periods per unit
- · CO<sub>2</sub> emission factors per unit
- · Operational constraints (minimum up/down time) per unit
- Must-run constraints per unit
- 2. Hydro Power Plants (HPPs)
  - General data (plant name, number of units)
  - · Operational status for each unit for target year 2030
  - Plant type (run of river, storage or pumped storage plant)
  - Maximum net output power per unit
  - Minimum net output power per unit
  - Biological minimum production
  - Maximum net output power per unit in the case of pumped storage plants
  - Minimum net output power per unit in case of pumped storage plants
  - The efficiency of pumped storage plants
  - Monthly generations for 3 hydrological conditions: average, dry and wet
- 3. Renewable Energy Sources (RES) for Referent and High Scenario
  - Installed capacities (solar)
  - Installed capacities (wind)
  - The hourly capacity factor for 10 characteristic climatic years: 2006-2015 (solar)
  - The hourly capacity factor for 10 characteristic climatic years: 2006-2015 (wind)
- 4. Demand in Referent Scenario
  - Annual consumption expected in 2030 (TWh)
  - Hourly load profiles for 10 characteristic climatic years: 2006-2015



- 5. Network Capacity
  - NTC values applied as cross-border limits for energy exchange

For any unavailable data, the Consultant applied other verified and publicly available official data, data from previous BSTP studies in addition to the consultants' documents and estimates. The data inputs primarily originate from the TYNDP and MAF datasets available at ENTSO-E platform.

The nine subsections below describe the data-gathering approach and modeling inputs in support of the analysis. They include the following: load, wind and solar profiles, hydro power plant generation, thermal power plants, fuel and  $CO_2$  prices and the impact of neighboring power systems.

## IV.1.1 Load, Wind and Solar Hourly Profiles

The expected annual demands were provided by the member TSOs. If the TSOs could not provide hourly load profiles for 10 climatic years, the Consultant utilized hourly load profiles from previous BSTP studies.

For the referent RES scenarios, the Consultant applied the expected installed RES capacities, provided by the TSOs. In case if TSO did not provide installed capacities in wind and solar power plants for high RES scenario, consultant applied capacities that are 25% higher than referent ones.

For all zones outside BSTP regiona and in cases when TSO did not provide wind and/or solar hourly capacity factors, the Consultant applied data from previous BSTP studies, which are based on publicly available databases from ETH Zurich<sup>2</sup>.

### **IV.1.2 Generation from Hydro Power Plants (HPPs)**

Each BSTP TSO provided generation input at least for the average hydrological conditions on an annual level.

If monthly generation in different hydrological conditions were not provided, the Consultant estimated generation based on the generation of similar HPPs. If the only data available is for average hydrology, dry and wet generations are estimated based on previous BSTP studies.

### **IV.1.3 Technical and Economic Parameters – Thermal Power Plants**

Unless otherwise specified in the data gathering spreadsheet, the Consultant applied general technical and economic parameters for all TPPs, as shown in the following tables (Table 1 and Table 2).

<sup>&</sup>lt;sup>2</sup> https://www.renewables.ninja/



Category #	Fuel	Туре	Efficiency range in NCV terms	Standard efficiency in NCV terms	CO₂ emission factor	Variable O&M cost	Min Time on	Min Time off	Heat Rate (GJ/MWh)
			%	%	kg / Net GJ	Euro/MWh	hours	hours	%
1	Nuclear	-	30% - 35%	33%	0	9	12	12	10.9
2		old 1	30% - 37%	35%	94	3.3	8	8	10.3
3	Hard cool	old 2	38% - 43%	40%		3.3	6	6	9.0
4	Hard coar	New	44% - 46%	46%		3.3	5	5	7.8
5		CCS	30% - 40%	38%	9.4	6.6	7	7	9.5
6		old 1	30% - 37%	35%		3.3	11	11	10.3
7	Lianita	old 2	38% - 43%	40%	101	3.3	9	9	9.0
8	Lignite	New	44% - 46%	46%		3.3	8	8	7.8
9		CCS	30% - 40%	38%	10.1	6.6	10	10	9.5
10		conventional old 1	25% - 38%	36%		1.1	5	5	10.0
11		conventional old 2	39% - 42%	41%	57	1.1	5	5	8.8
12		CCGT old 1	33% - 44%	40%	57	1.6	3	3	9.0
13	Gas	CCGT old 2	45% - 52%	48%		1.6	3	3	7.5
14		CCGT new	53% - 60%	58%		1.6	2	2	6.2
15		CCGT CCS	43% - 52%	51%	5.70	3.2	4	4	7.1
16		OCGT old	35% - 38%	35%	57	1.6	1	1	10.3
17		OCGT new	39% - 44%	42%	- 57	1.6	1	1	8.6
18	Light oil	-	32% - 38%	35%	78	1.1	1	1	10.3
19	Hopwoil	old 1	25% - 37%	35%	70	3.3	3	3	10.3
20	rieavy oli	old 2	38% - 43%	40%	10	3.3	3	3	9.0
21	Oil cholo	old	28% - 33%	29%	100	3.3	11	11	12.4
22	On shale	new	34% - 39%	39%	100	3.3	8	8	9.2

Table 1: General te	echnical and economic	parameters for	TPPs from	TYNDP 2018	common base
---------------------	-----------------------	----------------	-----------	------------	-------------

#### Table 2: Additional technical parameters for TPPs from TYNDP 2018 common base

Category #       Fuel       Type       Forced outage       Planned outage       Minimum stable generation         1       Nuclear       -       5%       7       54       15%       50%         2       -       5%       7       54       15%       50%         3       Hard coal       0ld 1       10%       1       27       15%       43%         4       0ld 2       10%       1       27       15%       43%         6		Unavailability						Minimum
Category #       Fuel       Type       annual rate       Mean time to repair       annual rate       winter       generation         1       Nuclear       -       5%       7       54       15%       50%         2				Forced	outage	Planned	stable	
Mark       Mark       Days       number of days       % of annual number of days       (% of max power)         1       Nuclear       -       5%       7       54       15%       50%         2       -       5%       7       54       15%       50%         3       Hard coal       0id 1       10%       1       27       15%       43%         4       0id 2       10%       1       27       15%       43%         5       0id 1       10%       1       27       15%       43%         6	Category #	Fuel	Туре	annual rate	Mean time to repair	annual rate	winter	generation
$ \begin{array}{c c c c c c c c c c c c c c c c c c c $				%	Days	number of days	% of annual number of days	(% of max power)
$ \begin{array}{c c c c c c c c c c c c c c c c c c c $	1	Nuclear	-	5%	7	54	15%	50%
$ \begin{array}{c c c c c c c c c c c c c c c c c c c $	2		old 1	10%	1	27	15%	43%
$ \begin{array}{c c c c c c c c c c c c c c c c c c c $	3	Hord cool	old 2	10%	1	27	15%	43%
5       Lignite CCS       7.50%       1       27       15%       43%         6       Image: constraint of the state of the s	4	Haru cuar	new	7.50%	1	27	15%	43%
$ \begin{array}{c c c c c c c c c c c c c c c c c c c $	5		Lignite CCS	7.50%	1	27	15%	43%
$ \begin{array}{c c c c c c c c c c c c c c c c c c c $	6		old 1	10%	1	27	15%	43%
8       Lignite       new       7.50%       1       27       15%       43%         9       Hard coal CCS       7.50%       1       27       15%       43%         10       conventional old 1       8%       1       27       15%       43%         11       conventional old 2       8%       1       27       15%       35%         11       conventional old 2       8%       1       27       15%       35%         12       Gas       CCGT old 1       8%       1       27       15%       35%         13       Gas       CCGT old 2       8%       1       27       15%       35%         14       CCGT old 2       8%       1       27       15%       35%         15       CCGT old 2       8%       1       27       15%       35%         16       CCGT old 8%       1       13       15%       30%         17       OCGT old 8%       1       13       15%       30%         18       Light oil       -       8%       1       13       <	7		old 2	10%	1	27	15%	43%
9       Hard coal CCS       7.50%       1       27       15%       43%         10 conventional old 1       8%       1       27       15%       35%         11 conventional old 2       8%       1       27       15%       35%         11 conventional old 2       8%       1       27       15%       35%         12 CCGT old 1       8%       1       27       15%       35%         13 Gas CCGT old 1       8%       1       27       15%       35%         14 CCGT old 2       8%       1       27       15%       35%         15 CCGT cld 2       8%       1       27       15%       35%         16 CCGT cld 8%       1       13       15%       30%         17 OCGT new       5%       1       13       15%       30%         18       Light oil       -       8%       1       13       15%       35%         20       Heavy oil       old 1       10%       1       27	8	Lignite	new	7.50%	1	27	15%	43%
10       onventional old 1       8%       1       27       15%       35%         11       conventional old 2       8%       1       27       15%       35%         12       Correntional old 2       8%       1       27       15%       35%         13       Gas       CCGT old 1       8%       1       27       15%       35%         14       CCGT old 2       8%       1       27       15%       35%         14       CCGT old 2       8%       1       27       15%       35%         15       CCGT old 2       8%       1       27       15%       35%         16       CCGT old 8%       1       13       15%       30%         17       OCGT new       5%       1       13       15%       30%         18       Light oil       -       8%       1       13       15%       35%         20       Heavy oil       old 1       10%       1       27       15%       35%         21       Oil shale       old       10%       1       27<	9		Hard coal CCS	7.50%	1	27	15%	43%
11       conventional old 2       8%       1       27       15%       35%         12       Gas       CCGT old 1       8%       1       27       15%       35%         13       Gas       CCGT old 1       8%       1       27       15%       35%         14       CCGT old 2       8%       1       27       15%       35%         14       CCGT old 2       8%       1       27       15%       35%         15       CCGT new       5%       1       27       15%       35%         16       CCGT cCS       5%       1       27       15%       35%         16       OCGT new       5%       1       13       15%       30%         17       OCGT new       5%       1       13       15%       30%         18       Light oil       -       8%       1       13       15%       35%         19       Heavy oil       old 1       10%       1       27       15%       35%         20       Heavy oil       old 2       10%       1	10		conventional old 1	8%	1	27	15%	35%
12       Gas       CCGT old 1       8%       1       27       15%       35%         13       Gas       CCGT old 2       8%       1       27       15%       35%         14       CCGT old 2       8%       1       27       15%       35%         15       CCGT new       5%       1       27       15%       35%         16       CCGT CCS       5%       1       27       15%       35%         17       OCGT old       8%       1       13       15%       30%         18       Light oil       -       8%       1       13       15%       35%         19       Heavy oil       old 1       10%       1       27       15%       35%         20       Heavy oil       old 1       10%       1       27       15%       35%         21       Oil shale       old       10%       1       27       15%       40%	11		conventional old 2	8%	1	27	15%	35%
13       Gas       CCGT old 2       8%       1       27       15%       35%         14       CCGT new       5%       1       27       15%       35%         15       CCGT ccs       5%       1       27       15%       35%         16       CCGT ccs       5%       1       27       15%       35%         0CGT old       8%       1       13       15%       30%         17       OCGT new       5%       1       13       15%       30%         0CGT new       5%       1       13       15%       30%         18       Light oil       -       8%       1       13       15%       35%         19       Heavy oil       old 1       10%       1       27       15%       35%         20       Heavy oil       old 2       10%       1       27       15%       35%         21       Oil shale       old       10%       1       27       15%       40%         22       Oil shale       new       7.50%       1       27	12		CCGT old 1	8%	1	27	15%	35%
14       CCGT new       5%       1       27       15%       35%         15       CCGT CCS       5%       1       27       15%       35%         16       OCGT old       8%       1       13       15%       30%         17       OCGT new       5%       1       13       15%       30%         18       Light oil       -       8%       1       13       15%       35%         19       Heavy oil       old 1       10%       1       27       15%       35%         20       Heavy oil       old 1       10%       1       27       15%       35%         21       Oil shale       old       10%       1       27       15%       40%         22       Oil shale       new       7.50%       1       27       15%       40%	13	Gas	CCGT old 2	8%	1	27	15%	35%
$ \begin{array}{c c c c c c c c c c c c c c c c c c c $	14		CCGT new	5%	1	27	15%	35%
16       OCGT old       8%       1       13       15%       30%         17       OCGT new       5%       1       13       15%       30%         18       Light oil       -       8%       1       13       15%       35%         19       Heavy oil       old 1       10%       1       27       15%       35%         20       Old 2       10%       1       27       15%       35%         21       Oil shale       old       10%       1       27       15%       40%         22       Oil shale       new       7.50%       1       27       15%       40%	15		CCGT CCS	5%	1	27	15%	35%
17       OCGT new       5%       1       13       15%       30%         18       Light oil       -       8%       1       13       15%       35%         19       Heavy oil       old 1       10%       1       27       15%       35%         20       Heavy oil       old 2       10%       1       27       15%       35%         21       Oil shale       old       10%       1       27       15%       40%         22       Oil shale       new       7.50%       1       27       15%       40%	16		OCGT old	8%	1	13	15%	30%
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	17		OCGT new	5%	1	13	15%	30%
19       Heavy oil       old 1       10%       1       27       15%       35%         20       old 2       10%       1       27       15%       35%         21       old 10%       1       27       15%       40%         22       old 10%       1       27       15%       40%	18	Light oil	-	8%	1	13	15%	35%
20       Indexy on       old 2       10%       1       27       15%       35%         21       Oil shale       old       10%       1       27       15%       40%         22       Oil shale       new       7.50%       1       27       15%       40%	19	Heavy oil	old 1	10%	1	27	15%	35%
21       Oil shale       old       10%       1       27       15%       40%         22       new       7.50%       1       27       15%       40%	20	rieavy off	old 2	10%	1	27	15%	35%
22 On shale new 7.50% 1 27 15% 40%	21	Oil shala	old	10%	1	27	15%	40%
	22	On shale	new	7.50%	1	27	15%	40%



## IV.1.4 Fuel and CO<sub>2</sub> Prices

As most member TSOs were unable to provide exact numbers for fuel and  $CO_2$  prices, the Consultant applied consistent and comparable values for the analyzed countries and market areas. The Consultant applied the 2030 fuel prices from the TYNDP 2020 database (Table 3), with the exception of Georgia and Armenia, where fuel prices were taken from the BSTP Armenia-Georgia sub-regional Study.

		2020	2021	2023	20	25		2030			2040	
					BE	G2C	NT	DE	GA	INT	DE	G
	Nuclear	0.47	0.47	0.47	0.	47		0.47			0.47	
	Lignite	1.1	1.1	1.1	1	.1		1.1			1.1	
	Oil shale	2.3	2.3	2.3	2	.3		2.3			2.3	
€/GJ	Hard Coal	3.0	3.12	3.4	3.	79		4.3			6.91	
	Natural Gas	5.6	5.8	6.1	6.	46		6.91			7.31	
	Light Oil	12.9	14.1	16.4	18	3.8		20.5			22.2	
	Heavy Oil	10.6	11.1	12.2	13	3.3		14.6			17.2	
€/tCO <sub>2</sub>	CO <sub>2</sub> price	19.7	20.4	21.7	23	56	27	53	35	75	100	80

#### Table 3: Fuel and CO<sub>2</sub> prices in 2030 from TYNDP 2020

To input the CO<sub>2</sub> price, the Consultant used 27  $\epsilon/tCO_2$ , the same amount as described in the TYNDP 2020 National Trends (NT)<sup>3</sup> scenario analyzed in the TYNDP 2020.

The  $CO_2$  price must be applied for all EU member states. Concerning non-EU countries, the Consultant applied the same  $CO_2$  tax in the Turkey, Ukraine and Moldova. This is applied with the expectation that by 2030, Ukraine and Moldova will be fully synchronized into the ENTSO-E and that there will be key requirements from the EC or EnC related to the  $CO_2$  emission reductions, which will refer to Turkey as well. However, implementation of  $CO_2$  tax in Georgia and Armenia is not expected.

<sup>&</sup>lt;sup>3</sup> The central policy scenario of TYNDP 2020, recognizing national and EU climate targets, notably the draft National Energy and Climate Plans (NECPs)



### **IV.1.5 Neighboring Power Systems**

This Study considers seven power systems in the Black Sea Region. These power systems are modeled on a plant-by-plant level of detail<sup>4</sup>, with a simplified representation of the transmission network.

In order to achieve better modeling accuracy and to adequately model the exchange of electricity between the Black Sea region and neighboring power systems, it was important to include them in the wider regional market model.

The Study considered three approaches to model the neighboring systems:

- "Plant by plant" or technology cluster level of modeling for the SEE and EE countries
- Distant market zone (Central Europe) modeled as a power exchange
- Forecasted electricity exchange, in the case of Central Asia

The following is a detailed explanation of each approach:

### IV.1.6 Technology Clusters or "Plant by Plant" Level of Modeling

The BSTP model includes neighboring market zones in Eastern and South Eastern Europe (Poland, Slovakia, Hungary, Serbia, Montenegro, Croatia, Slovenia, Bosnia & Herzegovina, North Macedonia, Albania, Greece) that are modeled with varying levels of detail:

- Demand: total demand is defined at the hourly level and modeled with one demand center per country;
- Conventional generating units (TPP, NPP, HPP, PSHPP): per power plant or technological clusters, with corresponding technical and economic parameters (min and max capacity, operating costs, availability, available weekly generation for hydro power plants, other operating constraints, etc.);
- Renewable sources (wind, solar, biomass): total capacity per technology + generation at the hourly level with hourly profiles that correspond to available capacity factors, this generation is treated as "must run";
- Interconnection grid constraints with neighboring systems: defined as NTCs taken from TYNDP database.

All of the data listed above is sourced from the ENTSO-E TYNDP databases.

### IV.1.7 Distant Market Modeled as Power Exchange

For distant market zones, such as Central Europe, wholesale market prices were applied for 2030 from the TYNDP 2020 Scenario Report, which contains average yearly marginal cost indicators for

<sup>&</sup>lt;sup>4</sup> With the except of Turkey, which has been modeled at the technology cluster level



the ENTSO-E. That average yearly price is used to scale the different prices presented in the TYDNP 2018 for each market separately. Table 4 shows the assumptions for average yearly prices on the modeled external market.



Market	Average Annual Marginal Price (€/MWh)
Central Europe	32

In order to model the variation of hourly prices throughout the year, a time series of observed market prices in the respective electricity markets for the last three years are applied to create an hourly profile. Therefore, the hourly profile of electricity prices for Central Europe were based on the observed market prices from 2017 to 2019 on the European Energy Exchange (EEX), i.e. EPEX SPOT prices for Germany and Austria.

## **IV.1.8 Forecasted Electricity Exchange (Armenia – Central Asia)**

Armenia does not produce domestic gas and relies on imports from Russia. In addition to its supply from Russia, there is also a gas supply from Centra Asia. Armenia is contractually obligated to deliver 3 kWh of electricity for each cubic meter of gas coming from Central Asian partner. In 2017, as a part of the "gas-for-electricity" swap agreement, Armenia exported 1218 GWh to its Central Asian partner and it is assumed this arrangement will continue until 2030.

Central Asia is included in the BSTP model, as envisaged export under the "gas-for-electricity" agreement (1,218 GWh at the annual level).



## **IV.2** Summary of the input data for all countries

This chapter reviews the expected status of all power systems for the target year 2030, in alphabetical order, along with an overview of the data, assumptions and proxies that are used to develop the corresponding model in the Antares Software Tool.

All relevant parameters were presented within Interim Report, in order to enable each BSTP member to verify their plausibility and confirm their usability for upcoming forecasts and analyses. Review of the agreed and verified data for each BSTP member are presented in Appendix.

Several tables with overview of the expected development of consumption and generation per different technologies are presented below:

		Referent scenario					
BSTP Member	Demand in 2017/2018 (TWh)	Growth rate from 2018 to 2030	Demand in 2030 (TWh)				
AM	6.20	1.71%	7.70				
BG	34.10	0.76%	37.35				
GE	13.65	5.00 %	23.34				
MD	6.06	1.09%	6.90				
RO	57.90	0.81%	63.50				
UA	149.13	1.05%	169.00				
TR	301.00	2.7%	414.00				
TOTAL	571.04	2.01%	721.79				

#### Table 5: Referent demand growth

Average consumption growth rate is around 2% although majority of the countries have the rate around 1% or less. The reason is obvious impact of high rate in Turkey which has a consumption higher than the sum of consumption in all other BSTP members. This impact is also visible at the following Figure 6.





Figure 6: Consumption growth rates

The next four tables summarize the changes expected across BSTP market areas in installed generation capacities per technology from 2018 to 2030.

As Table 6 indicates, significant increase in wind power capacity in the coming decade could be expected. Increase is in the range of 16842 MW to 21175 MW (referent vs high RES scenario), which is 2.5 to 3.1 times more in WPPs than in 2018. In a number of cases, in the 2018 starting point, installed wind generation was zero or near zero. The largest growth of WPP capacities in absolute terms by 2030 is expected in TR (more than 11,000 MW) while in relative terms, the largest growth is anticipated in GE and MD where practically no capacity is present currently.

BSTP Member	Total WPP installed capacity 2018 (MW)	Total installed WPP capacity 2030 (MW)	Increase from 2018 (MW)
		Ref. / High	Ref. / High
AM	4	20 / 50	16 / 46
BG	700	887 / 1,109	187 / 409
GE	21	1,300 / 2,500	1,279 / 2,479
MD	31	742 / 1,060	711 / 1,029
RO	2,977	4,200 / 5,100	1,223 / 2,123
UA	704	4,393 / 6,641	3,689/5,937 (>5 times)
TR	7,591	18,415/20,000	11,067/12,652 (140%)
TOTAL	11,785	29,957/36,460	18,172/24,675

#### Table 6: Installed wind power plant (WPP) capacities

Even more rapid development is expected in solar power capacity. There will be an additional 21244 - 31972 MW (referent vs high RES scenario) of SPPs in the region, or 2 - 3 times more than in 2018,



as given in the following table. By far the largest installed SPP capacity (and almost half of the regional new SPP capacity) is expected in Turkey, followed by Ukraine. In 2030, these two market areas combined are expected to comprise 80% and 75% of SPP capacity in the region, respectively, in the referent and high RES scenarios.

BSTP Member	Total SPP installed capacity 2018	Total installed SPP capacity 2030 (MW)	Increase from 2018 - 2030 (MW)
	(MW)	Ref. / High	Ref. / High
AM	19	1,000 / 1,200	981 / 1,181
BG	1,052	2,929 / 3,661	1,877 / 2,609 (>3 times)
GE	0	550 / 2,200	550 / 2,200
MD	3	119 / 170	116 / 167
RO	1,262	2,000 / 3,700	738 / 2,438 (>2 times)
UA	2,667	7,874 / 11,669	5,207 / 9,002 (>3 times)
TR	5,997	17,400/20,000	11,775/14,375 (>2 times)
TOTAL	10,628	31,872/42,600	21,244/31,972

#### Table 7: Installed solar power plant (SPP) capacities

The following table shows expected changes in total installed hydro capacity by 2030. All BSTP members, except BG and MD, are planning to increase total HPP capacity. The most significant changes in the period 2018-2030, in absolute terms, are expected in Turkey. On the level of the entire region, total increase in installed HPPs capacity will be significant, but almost all changes are expected in Turkey. It should be also noted that capacity of PS HPPs in the region will increase, especially in GE and UA. There is new PS HPPs of 570 MW planned to be in operation in Georgia in 2030, while in Ukraine, new 1329 MW in pump-storage HPPs will be added to existing 1509 MW.

#### Table 8: Installed hydro power plant (HPP) capacities

BSTP Member	Total HPP installed capacity 2018 (MW)	Total installed HPP capacity 2030 (MW)	Increase from 2018 - 2030 (MW)
AM	1,335	1,470	135
BG	3,207	3,207	0
GE	3,070	6,271	3,201 (100%)
MD	61	61	0
RO	6,420	6,742	308
UA	4,704	4,842	138
TR	28,499	37,064	8,565 (30%)
TOTAL	46,725	62,035	15,296



Finally, the following table here shows expected changes (both positive and negative) in total installed capacities in thermal power, including nuclear power plants from 2018 to 2030. Four BSTP members are planning to decrease total TPP capacity while increase is expected in GE, RO and TR. The most significant change in this period, in absolute terms, is observed in Ukraine. Ukraine plans to decommission more than 14,000 MW of TPPs (coal fired units) by 2030. On the other hand, the largest TPP increase, in absolute terms, is expected in Turkey with a capacity increase of almost 2,000 MW, mainly due to increase of 4,500 MW in nuclear capacity.

BSTP Member	Total TPP installed capacity 2018 (MW)	Total installed TPP capacity 2030 (MW)	Increase from 2018 - 2030 (MW)
AM	1,600	1,440	-160
BG	7,442	7,269	-173
GE	925	1,119	194
MD	2,648	2,643	-5
RO	8,198	8,635	437
UA	34,602	19,881	-14,721 (-40%)
TR	46, 862	55,140	8,278
TOTAL	104,324	92,337	-11,987

#### Table 9: Installed thermal power plant (TPP) capacities

Changes from 2018 to 2030 are significant in almost all power systems. However, dominant installed generation capacity will remain in TPPs and HPPs, around 40% in TPPs and 30% in HPPs.

WPPs and SPPs installed capacity share in BSTP region will increase from 13% to 30% with almost same share in WPPs and SPPs. Looking at each BSTP member, in some cases starting from almost zero share in 2018, share in WPPs and SPPs will reach similar level in all countries in 2030, around 25-30%.





Figure 7: Monthly energy consumption (GWh) for 2030 – Armenia

## IV.3 Results of the market simulations

Market results are obtained for two different scenarios, ref. RES and high RES, as it is described in chapter II.2. In short, ref. RES represents a scenario with the expected RES development in 2030, while high RES represents a scenario with the higher RES penetration, either given by the TSO or estimated as +25% of the increase in comparison with the referent scenario. For both analyzed scenarios following results are presented:

- Overview of main system operating indicators
- Generation mixes and consumptions
- Generation of fossil fuel-fired TPPs
- CO2 emissions
- Spillages
- Net interchanges
- Prices

Each of the listed results is presented per each BSTP country, and for both scenarios, in side by side manner in order to facilitate comparison of results.



### IV.3.1 Armenia

Generation mix and selected set of indicators, as the main results of market analysis for Armenia, are presented in Figure 8 and Figure 9, respectively.



Figure 8: Generation mix of Armenia in 2030 – ref. RES vs high RES

By observing results from Figure 8 in conjunction with indicators shown in and Figure 9, the following can be concluded for Armenian power system operation in 2030 in high RES scenario in comparison with ref. RES scenario:

- RES generation will be increased from 1.6 TWh in ref. RES scenario to almost 2TWh in high RES scenario (+23%).
- At the same time generation from fossil fuel fired TPPs will be decreased from 3.7 TWh to 2.9 TWh (-13%). With this, CO2 emission will be also decreased from 1.55 mil.T CO<sub>2</sub> to 1.16 mil.T CO<sub>2</sub> (-25%).
- With greater RES generation, spillages will be increased from 0.1 TWh to 0.4 TWh. It should be noted that RES generation increase of around 0.4 TWh will lead to a spillage increase of around 0.3 TWh as result. This means that almost all additional generation from RES would be curtailed, which should not be allowed.

A situation like this points to the need for more detailed analyses that should be done with the aim to find the measures and potential solutions in the provision of the flexibility to the system (storages, regional market integration, balancing cooperation,...) before putting in operation this high level of RES capacities.



- Additional RES generation and spillages will lead to a decrease in prices from 33.7 \$/MWh to 22.7 \$/MWh, either due to the engagement of less expensive TPPs or due to zero prices during hours with spillages.
- Although prices will decrease, the export will be also decreased from 3.2 TWh to 2.3 TWh (-29%). This drop of around 0.9 TWh is almost the same as the decrease in fossil fuel TPP generation. Having in mind that Armenia could export electricity only to Georgia and Central Asia (limited to 1.2 TWh) and that in high RES scenario Georgia would also increase export and decrease prices, the reason for Armenian export decrease could be found in the fact that in high RES scenario, Armenian TPPs will be less competitive.

In Armenia, an increase of around 0.4 TWh of RES generation will be allocated almost entirely to increase of spillages (around 0.3 TWh) which will provoke a decrease in prices. In high RES Scenario, there is a high excess of generation in Georgia and Armenian power plants become less competitive than in ref. RES scenario, which leads to a decrease in TPPs generation and a decrease in export of around 1 TWh.



Figure 9: Main system operating indicators in Armenia in 2030 – ref. RES vs high RES



Having in mind that additional RES capacities, besides the needs for flexibility, also increase the needs for balancing reserve, we checked if the estimated required reserve (FCR+FRR<sup>5</sup>) can be satisfied with unengaged capacity in TPPs and HPPs with storages. In the case of Armenia, the required balancing reserve of 100 MW can be provided in all hours during the year in all analysed climatic years and hydrological conditions.

## IV.3.2 Bulgaria

50,000 45,000 40,000 35,000 30,000 GWh 25,000 20,000 15,000 10,000 5,000 0 ref.RES high RES Other 0 0 🖬 Gas 413 207 Coal 0 0 🖬 Lignite 16811 16356 Nuclear 14667 14667 Solar 3853 4816 Wind Wind 1678 2098 🖬 Hydro 4886 4954 - Consumption 36986 37076

Generation mix and selected set of indicators, as the main results of market analysis for Bulgaria, are presented in Figure 10 and Figure 11, respectively.

#### Figure 10: Generation mix of Bulgaria in 2030 - ref. RES vs high RES

Considering the Generation mix presented in Figure 10, in conjunction with the main system indicators depicted in Figure 11, the following conclusions could be drawn about the operation of the Bulgarian power system in the high RES scenario, in comparison with ref. RES:

• RES generation will rise from 5.5 TWh to 6.9 TWh (+25%).

<sup>&</sup>lt;sup>5</sup> Estimated reserve is based on balancing reserve applied in BSTP Adequacy Study from 2019, which is increased by 4% of corresponding RES increase



- Fossil fuel fired TPPs will decrease their generation from 17.2 TWh to 16.6 TWh (-4%), which will lead to a decrease of CO2 emission from 15.9 mil.T to 15.3 mil.T.
- At the same time, the export of Bulgaria will be increased from 5.3 TWh to 6 TWh (+13%). This increase of 0.7 TWh is almost equal to the difference between RES generation increase and TPP generation decrease. It means that in case of increased RES generation, part of the thermal generation fleet becomes non-competitive. Then, one part of the increase in RES generation will compensate for a decrease of TPP generation, while the other part of the RES generation increase, will lead to an increase in export.
- Higher RES capacities increase the need for flexible sources, so an increase of the PS HPPs utilization is presented in Table 10. Engagement in pumping mode is somewhat larger due to the PS HPP inefficiency.

Generation from PS HPPs (GWh)	All hydrological conditions			Wet hydrological conditions	Average hydrological conditions	Dry hydrological conditions
	Expected <sup>6</sup>	Min	Max	Expected	Expected	Expected
Ref. RES	56.2	31.3	86.9	50.4	57.1	60.9
High RES	124.0	81.2	165.8	112.3	125.9	133.8
Difference	67.8	49.9	78.9	61.9	68.8	72.9

#### Table 10: PS HPPs generation in Bulgaria

Generation from PS HPP in the high RES scenario is more than doubled in comparison with ref. RES scenario, because greater non-costly RES generation gives a higher possibility for pumping and storing energy for utilization in some other hours. Different hydrological conditions do not have a big impact on the generation of this type of HPPs.

• As a result, greater RES generation leads to a decrease in prices from 57.8 \$/MWh to 55.9 \$/MWh (-3%). Namely, an increase in RES generation, means that cheaper power plants become marginal.

In Bulgaria, an increase of around 1.4 TWh of RES generation will be allocated to the decrease of TPP generation (around -0.6 TWh), and increase of export (around 0.7 TWh).

<sup>&</sup>lt;sup>6</sup> Expected values represent average of a set of MC years, Min and Max values represent extremes.





Figure 11: Main system operating indicators in Bulgaria in 2030 – ref. RES vs high RES

As in the case of Armenia, the fulfillment of the estimated required reserve (FCR+FRR) has been checked, and, in the case of Bulgaria, the required balancing reserve of 400 MW can be provided in all hours during the year in all analysed climatic years and hydrological conditions.

## IV.3.3 Georgia

Generation mix and selected set of indicators, as the main results of market analysis for Georgia, are presented in Figure 12 and Figure 13, respectively.



Figure 12: Generation mix of Georgia in 2030 – ref. RES vs high RES

Considering the Generation mixes presented in Figure 12, in conjunction with main system indicators depicted in Figure 13 for both scenarios, conclusions regarding the operation of the Georgian power system in 2030 are as follows:

- RES generation will be more than doubled in high RES scenario in comparison with ref. RES. It will be increased from 5.5 TWh to 12.4 TWh (+123%). It should be noted that in this Study, only generation from wind and solar power plants are considered as RES generation.
- At the same time generation from TPPs on fossil fuel will be decreased from 6.1 TWh to 4.9 TWh (-21%), which will lead to a decrease in CO2 emission from 3.5 mil. T to 2.7 mil. T (-21%).
- RES generation increase of almost 7 TWh will lead to an increase in spillages/curtailment from 1.4 TWh to 3.4 TWh. This means that 2 TWh (+28%) of additional generation from wind and solar power plants would be curtailed which is too high and points to the need for more detailed analyses that should be done with the aim to find the optimal solution for the provision of additional system flexibility, before putting in operation such a high level of RES capacities.
- In these analyses, it has been assumed that in 2030 in Georgia new pumped-storage HPP will be in operation. This power plant helps the Georgian (and regional) power system in the



provision of flexibility that is needed especially in scenarios with high levels of RES. regardless, the level of spillages remains high (see the previous bullet) and, in addition to this PS HPP, other solutions for flexibility provision should be investigated.

The engagement of this plant in generating (turbining) mode is presented in Table 11. Engagement in pumping mode is similar, just increased due to PS HPP inefficiency.

Generation from PS HPPs (GWh)	All hydrological conditions			Wet hydrological conditions	Average hydrological conditions	Dry hydrological conditions
	Expected <sup>7</sup>	Min	Max	Expected	Expected	Expected
Ref. RES	202.2	143.7	243.7	191.3	186.4	228.8
High RES	415.3	309.8	512.7	353.9	419.2	472.7
Difference	213.1	166.1	269.0	162.6	232.8	243.9

Generation from PS HPP in the high RES scenario is more than doubled in comparison with ref. RES scenario, because greater non-costly RES generation gives a higher possibility for pumping and storing energy for utilization in some other hours.

Its generation in average and wet hydrology is rather similar, while the maximum generation is reached in dry hydrological conditions. This is expected since in dry hydrological conditions, the system operates in a more variable manner, with higher maximums and lower minimums of generation from HPPs, which generate higher needs for PS HPP engagement.

- Increase of RES generation and spillages will lead to a decrease in prices from 34.6 \$/MWh to 23.1 \$/MWh (-33%) because with higher RES generation cheaper plants will become marginal and with more hours with spillages, more hours will have a price of 0 \$/MWh, which decreases the value of the average annual price.
- Additional generation from RES and decreased prices will enable an increase of export which will rise from 9.5 TWh to 13 TWh (+36%).

In Georgia, an increase of RES generation of 7 TWh will be allocated to the decrease of TPP generation (around -1.3 TWh), an increase of spillages (around +2 TWh) and, due to decreased prices, an increase of export (around +3.5 TWh).

<sup>&</sup>lt;sup>7</sup> Expected values represent average of a set of MC years, Min and Max values represent extremes.





Figure 13: Main system operating indicators in Georgia in 2030 – ref. RES vs high RES

As in previous cases, we checked if the estimated required reserve (FCR+FRR) is satisfied and in the case of Georgia, we have found that, required balancing reserve of 390 MW cannot be satisfied in 65 and 56 hours during the year, in ref. and high RES scenarios respectively. Analyses showed that a lack of the balancing reserve can be expected practically only during the flooding season.

### IV.3.4 Moldova

Generation mix and selected set of indicators, as the main results of market analysis for Moldova, are presented in Figure 14 and Figure 15, respectively.




Figure 14: Generation mix of Moldova in 2030 – ref. RES vs high RES

By observing generation mixes presented in Figure 14: , in conjunction with main system indicators presented in Figure 15, conclusions regarding the operation of the Moldovan power system in 2030 in high RES scenario, compared to ref. RES, are as follows:

- RES generation will grow from 1.5 TWh to 2.2 TWh (+43%) and it is almost only provided by wind power plants.
- RES increase will be compensated with a decrease of TPPs generation from 4 TWh to 3.6 TWh (-8%), which will lead to a decrease in  $CO_2$  emission from 3.1 mil. T to 2.8 mil. T (-9%). It should be noted that the generation from MGRES and exchange with Moldelectrica is limited to the current level (around 4 TWh).
- RES generation increase will also lead to a decrease of import from 1.1 TWh to 0.8 TWh (-29%).
- Higher RES generation also leads to a decrease of average annual price from 57.8 \$/MWh to 54.9 \$/MWh (-5%), due to the fact that cheaper power plants become marginal.



In Moldova, an increase of around 0.7 TWh of RES generation will be allocated to decrease of TPP generation (around -0.4 TWh), and decrease of import (around -0.3 TWh). It should be noted that the decrease in TPP generation comes from decreased MGRES generation.



Figure 15: Main system operating indicators in Moldova in 2030 – ref. RES vs high RES

Assessment of the estimated required reserve (FCR+FRR) fulfillment has been carried out also for Moldova, and, we concluded that a balancing reserve of 80 MW can be provided in all hours during the year and in all analysed climatic years and hydrological conditions.

# IV.3.5 Romania

Generation mix and selected set of indicators, as the main results of market analysis for Romania, are presented in Figure 16 and Figure 17, respectively.





#### Figure 16: Figure 16Generation mix of Romania in 2030 - ref. RES vs high RES

By jointly analyzing results presented in Figure 16 and in Figure 17, and by comparing high RES and ref. RES results, the following can be concluded:

- RES generation will be increased from 13.4 TWh in ref.RES scenario to 18.4 TWh in high RES (+37%).
- At the same time, fossil fuel TPP generation will fall from 29.4 TWh to 26.9 TWh (-8%), which leads to a decrease in CO2 emission from 26.2 mil.T to 24.5 mil.T (-7%).
- The net export of Romania will rise from 10.5 TWh to 12.7 TWh (+21%).
- Also, with higher RES generation, prices will be decreased, from 56.4 \$/MWh to 54.1 \$/MWh.

In Romania, an increase of around 5 TWh of RES generation will be allocated to decrease of TPPs generation (around -2.5 TWh), and increase of export (around + 2.2 TWh).





Figure 17: Main system operating indicators in Romania in 2030 – ref. RES vs high RES

As in previous cases, we checked if the estimated required reserve (FCR+FRR) is satisfied and in the case of Romania, we have found that, required balancing reserve of 1400 MW cannot be satisfied in 251 and 230 hours in average, during the year, in ref. and high RES scenarios respectively. Analyses showed that lack of the balancing reserve can be expected in all seasons except in spring.

### IV.3.6 Ukraine

Generation mix and selected set of indicators, as the main results of market analysis for Ukraine, are presented in Figure 18 and Figure 19, respectively.





Figure 18: Generation mix of Ukraine in 2030 - ref. RES vs high RES

Considering the Generation mixes presented in Figure 18, in conjunction with the main system indicators depicted in Figure 19 for both scenarios, conclusions regarding the operation of the Ukrainian power system in 2030 are as follows:

- RES generation will be increased from 21 TWh to 31.4 TWh (+50%).
- At the same time generation from TPPS on fossil fuel will be decreased from 14.7 TWh to 12.3 TWh (-16%), which will lead to a decrease in CO2 emission from 10.7 mil. T to 9.1 mil. T (-15%).
- Higher RES capacities increase the needs for flexible sources, so increases in the utilization of the PS HPPs are presented in Table 12. Engagement in pumping mode is similar, just somewhat increased for PS HPP inefficiency.



Generation from PS HPPs (GWb)	eneration All hydrological conditions m PS HPPs (GWh)		Wet hydrologica I conditions	Average hydrological conditions	Dry hydrological conditions	
(GWII)	Expected <sup>8</sup>	Min	Мах	Expected	Expected	Expected
Ref. RES	902,047	572,588	1,266,664	685,425	900,854	1,119,863
High RES	1,651,953	1,269,633	2,248,285	1,415,227	1,653,083	1,887,550
Difference	749,906	697,045	981,621	729,802	752,230	767,687

### Table 12: PS HPPs Generation in Ukraine

Generation of this type of power plant in the high RES scenario is almost doubled in comparison with ref. RES scenario, because greater non-costly RES generation gives the higher possibility for pumping and storing of energy, for utilization in some other hours. It should be noted that this type of HPPs has a high utilization factor in Ukraine, higher than in any of the BSTP countries. This is driven by the size and structure of the power generation portfolio: high participation of nuclear (flat) generation as well as high participation of nondispatchable RES generation. Also, since HPPs are an important source, ther is an impact of different hydrological conditions on the generation of PS HPPs.

- The increase of RES generation will lead to a decrease in prices from 62.2 \$/MWh to 56.8 \$/MWh (-9%) because with higher RES generation cheaper plants will become marginal.
- Also, an increase of must run RES generation will lead to a decrease of import from 18.8 TWh to 11.1 TWh (-41%).

In Ukraine, an increase of around 10.4 TWh of RES generation will be mainly allocated to the decrease of TPPs generation (around -2.4 TWh), and to decrease of import (around -7.7 TWh), followed by a decrease of wholesale prices in Ukraine.

<sup>&</sup>lt;sup>8</sup> Expected values represent average of a set of MC years, Min and Max values represent extremes.





Figure 19: Main system operating indicators in Ukraine in 2030 – ref. RES vs high RES

As in previous cases, the fulfillment of the estimated required reserve (FCR+FRR) has been checked, and, in the case of Ukraine, the required balancing reserve of 1400 MW can be provided in almost all hours during the year in all analysed climatic years and hydrological conditions. Results showed that reserve is not satisfied in 5 and 1 hour on average during the year, in ref. and high RES scenario, respectively.

## IV.3.7 Turkey

Generation mix and selected set of indicators, as the main results of market analysis for Turkey, are presented in Figure 20 and Figure 21, respectively.





Figure 20: Generation mix of Turkey in 2030 - ref. RES vs high RES

By observing results from Figure 20 in conjunction with indicators shown in Figure 21: , the following can be concluded for the Turkish power system operation in 2030 in ref. and high RES scenarios:

- In 2030, RES generation will rise from 75.6 TWh in ref. RES scenario to 83.8 TWh in high RES scenario (+11%).
- RES increase will be almost entirely compensated with a decrease in fossil fuel TPPs generation from 145.1 TWh to 137.7 TWh (-5%), which will lead to a decrease in  $CO_2$  emission from 78.3 TWh to 75.1 TWh (-4%).
- The increase of non-dispatchable RES generation will lead to a decrease in prices from 70.6 \$/MWh to 69.21 \$/MWh (-2%) because with higher RES generation cheaper plants will become marginal. Although, this decrease in prices can be considered negligible.
- Also, a small part of the RES generation increase will be allocated to a decrease in import from 24.4 TWh to 23.9 TWh (-2%).

In Turkey, an increase of around 8.2 TWh of RES generation will be mainly allocated to the decrease of TPPs generation (around -7.5 TWh), and decrease of import (around -0.5 TWh).





Figure 21: Main system operating indicators in Turkey in 2030 – ref. RES vs high RES

A check of the fulfillment of the estimated required reserve (FCR+FRR) has been carried out also for Turkey, and, we concluded that a balancing reserve of 2600 MW can be provided in all hours during the year in all analysed climatic years and hydrological conditions.



# **IV.4 Regional Summary**

In this chapter, results are presented on a regional level, in order to analyse changes in BSTP system operation as a whole and in order to compare BSTP countries' performance for selected indicators.

In Table 13 main results of Antares simulations, for all BSTP countries in ref. RES and high RES scenario are presented encompassing RES capacities and generation, forecasted annual consumption, expected generation, spillages, exchanges and prices.

Country	Scenario	RES (wind+solar) capacities (MW)	RES (wind+solar) generation (GWh)	Consumption (GWh)	Generation (GWh)	Spillages (GWh)	Net interchange (GWh)	Prices (\$/MWh)
A.M.	Ref	1,020	1,574	7,730	10,910	142	3,180	33.7
AM	High	1,250	1,936	7,730	10,003	432	2,273	22.7
PC	Ref	3,816	5,531	36,986	42,308	0	5,322	57.8
BG	High	4,770 6,914 37,076	43,098	0	6,022	55.9		
CE	Ref	1,850	5,543	23,518	33,044	1,346	9,526	34.6
GE	High	4,700	12,369	12,369 23,822 36,783	3,373	12,961	23.1	
MD	Ref	861	1,530	6,879	5,779	0	-1,100	57.8
MD	High	1,230	2,185 6,879 6	6,101	0	-778	54.9	
BO	Ref	6,200	13,399	63,316	73,830	0	10,514	56.4
ĸu	High	8,800	18,406	63,316	76,049	0	12,733	54.1
	Ref	12,267	20,968	169,624	150,828	0	-18,796	62
	High	18,310	31,429	170,619	159,553	0	-11,066	56.8
TD	Ref	35,815	75,591	412,871	388,516	19	-24,355	70.6
IK	High	40,000	83,833	412,871	388,999	77	-23,872	69.2
PCTD	Ref	61,829	124,135	720,924	705,215	1,507	-15,709	53.3
BSIP	High	79,060	157,072	722,313	720,586	3,882	-1,727	48.1

Table 13: Main system operating indicators for the BSTP region in 2030 – ref. RES vs high RES

In Figure 22, the generation mix for the BSTP region as a whole in ref. RES and high RES scenarios are depicted, also in Figure 23 selected indicators for the BSTP region as a whole is given, which represents the main results of market simulations.





### Figure 22: BSTP generation mix in 2030 - ref. RES vs high RES

Considering the BSTP generation mixes presented in Figure 21, in conjunction with main system indicators depicted in Figure 22 for both scenarios, conclusions regarding the operation of the BSTP power system as a whole, in 2030 are as follows:

- RES generation (Wind + Solar) will be increased from 124.1 TWh to 157.1 TWh (+27%). Wind generation will grow from 78 TWh to 96 TWh, while solar will rise from 46 TWh to 61 TWh. This is the consequence of the increase in wind capacities from 30 to 36 GW and in solar capacities form 32 to 42 GW.
- As one of the main consequences of increased RES generation, TPP generation will fall, from 220 TWh to around 205 TWh (- 7%). The majority of that decrease will come from decreased gas-fired generation due to the fact that higher RES generation means that most expensive power plants will be out of the merit order.
- Together with the decrease of fossil fuel fired TPP generation, CO2 emission will be decreased from 139.2 mil.T to 130.7 mil.T (-6%).



- Considering that the region as a whole is importer, the net import will be decreased from 15.7 TWh to -1.7 TWh (-89%), due to higher RES generation.
- At the same time, higher RES generation leads to lower prices, due to the fact that cheaper power plants become marginal, so the average annual price in BSTP region as a whole will fall from 53.3 \$/MWh to 48.1 \$/MWh (-10%)
- In some countries higher RES generation will lead also to increased spillages (like in Armenia and Georgia), due to the fact that in some hours generation is greater than consumption, cross border lines are congested and technical limitation of power plants don't allow a further decrease of generation. During these hours part of RES generation has to be curtailed. Spillages will be increased from 1.5 TWh to 3.9 TWh (+160%). Having in mind that these spillages are substantial for countries in which they appear, further flexibility analysis of respective power systems are advised.



Figure 23: Main system operating indicators for the BSTP region in 2030 – ref. RES vs high RES

Considering the fact that the BSTP region is comprised from countries which are different in size, population and electricity needs, it is impractical to directly compare them with energy indicators, such as TPP generation, CO2 emission and balances, so in Figure 24 average annual prices for each BSTP country and both scenarios are given, as a universal indicator.





### Figure 24: Average annual prices per BSTP country in 2030: ref. RES vs high RES

Conclusions regarding prices in 2030 are the following:

- BSTP countries are grouped in 3 price zones: Armenia and Georgia (around 25-35\$/MWh), Bulgaria, Moldova, Romania and Ukraine (around 55\$/MWh-60\$/MWh) and Turkey (around 70 \$/MWh). Armenia and Georgia have lower prices than the central part of the BSTP region due to cheaper gas (and non-CO2 taxes) and excess of HPPs generation, while prices in Turkey are the highest since it is a big importing market zone.
- Regarding the decrease in prices, Armenia and Georgia will have the largest decrease (around 35%) mainly due to increased spillages. Having in mind that both countries are exporters, this could decrease benefits from energy trade.
- Armenia can increase it's export only toward Georgia (export to Central Asia is considered limited) and spillages in Armenia and Georgia are connected. Having in mind that a large part of additional RES generation would be curtailed (spilled), the level of new RES capacities in Armenia and Georgia should be carefully considered.
- Prices in other BSTP countries will decrease from 2% in Turkey to 9% in Ukraine.
- Considering that Ukraine, Turkey and Moldova are net importers of electricity, a decrease in prices could have a positive impact on energy trade.





# V.1 System Modeling for Grid Analyses

For the network simulation, this Study applied the Regional Transmission System Models (RTSMs) for the following referent cases:

- the **Winter maximum load regime** (corresponding to the third Wednesday in January 2030 at 18:00 CET);
- the **Summer minimum load regime** (corresponding to the third Wednesday in May 2030 at 04:00 am CET)
- the **Summer maximum load regime** (corresponding to the third Wednesday in July at 11.00 CET and time in which maximum solar generation can be expected).

Each regime includes two variants related to RES integration:

- the expected/forecasted level of RES integration (MW) for 2030, and
- a higher level of RES integration, either one specified by the TSO, or as a default, a level 25% higher than the expected level

To create a corresponding regional BSTP network model, the Consultant first developed a review of the individual country models already present in the current regional BSTP model and updated at the end of 2019. Also, a preliminary analysis of the country TSO models was conducted and presented in the Interim Report. The same is presented in Appendix.

The initial network models then have been updated based on the data provided by the TSOs in the form of tables with a list of large-scale RES projects and their location in the grid. For each country, there were two lists: one related to the referent RES scenario and another referring to more aggressive, high RES scenario. Based on the initial models and these lists, two different sets of network models have been developed.

Updated individual models have been merged into regional models and these have been used for detailed AC load flow simulations. For each analyzed regime, the Consultant used generation dispatch obtained from the market simulations of the scenarios with different levels of RES.

In the following chapters we present the methodology we applied in selection of the characteristic hours and complete results of the network simulations in the presence of referent and high level of wind and solar capacities in year 2030.



# V.2 Selection of the hours that corresponds to specific regimes

There are three critical regimes selected for the network analysis, considered to be the most critical regarding high RES integration impact on transmission network:

- 1) Max load regime: Regime expected on third Wednesday in January 2030 at 18:00 CET
- 2) **Max WPP+SPP regime:** Regime expected in the hour in which maximum of the sum of wind and solar generation in the whole region is realized
- 3) **Max SPP regime:** Regime expected in the hour in which maximum of the solar generation in the whole region is realized

Selection of these three regimes (that corresponds to specific hour within a year) are based on the results of the market study, conducted on Monte Carlo principle with different climatic years (for both analyzed scenarios, referent and high RES), and represent load and generation pattern as well as cross-border exchanges, for the whole BSTP region.

Beside selection of the specific regime or hour, it was necessary to choose only one of the 10 climatic years, the one that corresponds to most specific climatic year from the analysed set of 10 years, from 2006 to 2015. The approach was as follows:

1. Winter max regime: The hour that corresponds to winter maximum regime is hour 402, January 17<sup>th</sup>, 6 pm. For this analyses only relevant was a selection of the climatic year and year 7 (2012) has been selected as the year in which sum of the generation from WPPs and SPPs in hour 402 is the lowest. This option has been intentionally chosen in order to check if the power system is able to provide secure and reliable transmission of power in case when production from RES is at minimum level and load is maximal.

In observed hour total generation from wind and solar power plants is 2571 MW (3029 MW), for the whole BSTP region. Generation from wind and solar power plants per each country in all selected regimes are presented in Table 14.

2. Selection of the regime with maximum SPP generation: The climatic year 3, as a year with maximum annual generation from SPPs in the whole BSTP region has been selected. Annual generation from SPPs in MC 3 (climatic year 2008) for the whole BSTP region is 47.4TWh and 58.8TWh in referent and high RES scenarios, respectively.

Then, hour in which SPPs generation is maximal has been selected – hour 3732. This hour corresponds to June 5<sup>th</sup> at 11 AM. The total generation from solar power plants for the whole BSTP region in observed hour is 22336 MWh and 29566 MWh in referent and high RES scenarios, respectively.

3. Selection of the regime with maximum WPP+SPP generation: The climatic year 7, as a year with maximum annual generation from WPPs and SPPs in the whole BSTP region has been



selected. Annual generation from WPPs and SPPs in year 7 (climatic year 2012) for the whole BSTP region is 129.4 TWh and 144.8TWh in referent and high RES scenarios, respectively.

Then, hour in which sum of the WPPs and SPPs generation is maximal has been selected – hour 5795. This hour corresponds to August 30<sup>th</sup> at 10 AM. The total generation from wind and solar power plants for the whole BSTP region in observed hour is 38411 MWh and 49990 MWh in referent and high RES scenarios, respectively.

Country	Hourly Winter max generation		x regime Max SPP		Max WPP+SPP		
	(MWh)	Referent RES	High RES	Referent RES	High RES	Referent RES	High RES
AM	SPP	0	0	900	1,080	659	790
АМ	WPP	9	23	1	3	0	1
DC	SPP	0	0	1,920	2,400	1,683	2,103
DU	WPP	69	86	8	10	572	715
CE	SPP	0	0	324	1,298	335	1,339
UE	WPP	78	150	226	435	1,170	2,250
МО	SPP	0	0	78	111	82	118
MD	WPP	51	73	149	212	348	497
DO	SPP	0	0	1,674	3,097	1,749	3,236
KU	WPP	752	914	278	337	2,139	2,597
тр	SPP	0	0	12,824	14,740	11,161	12,829
IK	WPP	1,538	1,671	1,898	2,062	10,162	11,037
114	SPP	0	0	4,616	6,840	4,875	7,224
UA	WPP	74	112	1,128	1,705	3,476	5,254
ретр	SPP	0	0	22,336	29,566	20,544	27,639
BSTP	WPP	2.571	3.029	3.688	4.764	17.867	22.351

### Table 14: Generation from WPPs and SPPs in selected regimes

It should be noted that in some cases (hours), production from WPPs and SPPs has been curtailed. It happens in Armenia and Georgia in high RES scenarios:

- in max SPP regime curtailment is 518 MW in AM and
- in max WPP+SPP regime curtailment is 489 MW in GE.

Curtailment has been shared between WPPs and SPPs proportionally to the actual generation.

In further network analyses, hourly load and dispatch has been taken from market simulations and applied in corresponding initial network models:

- for winter max regime winter max model has been used
- for max SPP and max WPP+SPP regimes summer max models have been used.



Required demand has been achieved by scaling total load found in referent models, maintaining constant P/Q ratio in order to achieve as realistic voltage values as possible.

# V.3 Results of the network analyses

## V.3.1 Armenia

Results obtained from the market simulations for selected timestamps which are applied to regional network models are given in the following tables.

	Max load		Max	SPP	Max WPP + SPP	
АМ	Ref	High	Ref	High	Ref	High
Load	1178.6	1178.6	998.3	998.3	929	929
Generation	1694	1599	1457	1667	1775	1070
Losses	40.4	37	46.7	59.2	54	41.8
Desired interchange	475	380	412	622	792	87

### Table 15: Totals - Armenia

Table 16: Generation per technology - Armenia

	Generation (MW)							
AM	Max load		Max SPP		Max WPP + SPP			
	Ref	High	Ref	High	Ref	High		
RoR	130	130	320	320	178	146		
Storage	242	237	62	90	151	133		
Gas	877	773	174	174	351	174		
Nuclear	436	436	0	0	436	344		
SPP	0	0	900	1080	659	272		
WPP	9	23	1	3	0	1		

Generation dispatch from market simulations has been implemented to network models per each power generating unit and RES has been modeled as negative loads located in specified nodes. Generation from renewables, obtained from market simulations as summed values per type, is distributed proportionally to original negative loads found in referent models.

Main characteristics of relevant regimes in the power system of Armenia, are the following:

• In the Max load regime, the production from renewable sources is at a minimum level and high load demand is mostly covered by conventional sources such as nuclear and thermal power plants.



- Regarding Max SPP regime, high generation from solar power plants covers most of the consumption and there is no power generated from nuclear power plant in this regime.
- As for Max WPP + SPP regime, in the specified hour solar generation capacities are curtailed causing less RES generation then in Max SPP regime. This is the consequence of the higher RES generation in Georgia.

Load flow simulations performed on updated network models indicate no violations of operational security limits in terms of voltages outside of permissible limits or overloading of elements.

Overview of voltages and loading of elements in the system is given in the following figures.



### Figure 25: Overview of voltages in Armenia



Figure 26: Overview of loadings in Armenia



Analysis of the results of power system simulations indicate that voltages in the power system of Armenia are not significantly impacted by higher RES integration in the system and remain similar in High RES scenarios compared to referent RES scenarios.

Loading of elements is in proportion with the balance of the country, indicated by higher average loading of elements and consequently losses in the system, in cases when export increases. This is clearly indicated in Max SPP regime since Armenian power system includes high solar capacities and small capacities in wind. In Max SPP+WPP regime, High RES scenario, solar generation capacities are curtailed, causing lower export of power, which is followed by decrease of average loading of elements and overall losses in the system.

Contingency analyses have been performed for all operating regimes and RES integration scenarios in order to identify possible network congestions and bottlenecks. In Armenian power system, single issue has been identified which violates N-1 security criterion. Specifically:

Outage of 400 kV line Ddmashen – Ayrum causes overloading of 220 kV line Alaverdy 2

 Vanadzor 2 and 220 kV line Alaverdy 2 – Ayrum. This issue occurs in all observed operating regimes and it is direct consequence of exchange of power via B2B link between Armenia and Georgia. Most significant impact is observed in Max SPP+WPP regime, referent RES scenario, where B2B link is utilized at its full capacity of 700 MW from Armenia to Georgia. It is important to notice that in case of the observed contingency, power exchanged via B2B link should be curtailed in order to preserve network security conditions, since remaining 220 kV network is not sufficient to support high energy exchange.

# V.3.2 Bulgaria

Overview of total load, generation, losses and export as well as generation per each type of technology for power system of Bulgaria is given in the following tables.

BG	Max load		Max	SPP	Max WPP + SPP		
	Ref	High	Ref	High	Ref	High	
Load	6144.4	6144.4	4095.3	4095.3	3902.7	3902.7	
Generation	6788	6816	4040	4522	6221	6784	
Losses	173.6	182.7	99.7	122.3	182.3	234.8	
Desired interchange	470	498	-155	327	2163	2726	

#### Table 17: Totals - Bulgaria

	Generation (MW)							
BG	Мах	load	Max SPP		Max WPP + SPP			
	Ref	High	Ref	High	Ref	High		
RoR	72	72	304	304	156	156		
Storage	1450	1461	0	0	0	0		
Coal	2212	2212	1808	1808	1810	1810		
Gas	985	985	0	0	0	0		
Nuclear	2000	2000	0	0	2000	2000		
SPP	0	0	1920	2400	1683	2103		
WPP	69	86	8	10	572	715		

### Table 18: Generation per technology - Bulgaria

In the Bulgarian network model, all renewables are modeled as machines and summed RES generation obtained in market simulations is divided between units proportionally to maximum power (installed capacities).

Main characteristics of the observed regimes are the following:

- In Max load regime, the production from renewable sources is at a minimum and high load demand is mostly covered by nuclear and thermal power plants.
- In Max SPP regime, solar power plants supply half of total demand in referent RES scenario and around 60% of total demand in high RES scenario, which exceeds the total production of all conventional power plants in the observed regime.
- As for Max WPP + SPP regime, the combined production of solar and wind power plants is at the highest level which is followed by increased export of power.

As a consequence of increased RES integration, losses are 23% higher in Max SPP regime and 29% higher in Max SPP+WPP, when high RES and referent RES scenarios are compared.

Overview of the minimum, average and maximum voltage values, as well as maximum and average loading of elements is given in the following figures.





Figure 27: Overview of voltages in Bulgaria



Figure 28: Overview of loadings in Bulgaria

Power flow analysis indicates that no significant voltage changes occur between referent RES and high RES scenarios in the power system of Bulgaria. In Max load regime there is no significant difference, while in Max SPP and Max SPP+WPP regimes loadings of elements' are increased in high RES scenarios, followed by slight decrease of voltages throughout the system.

Contingency analyses performed on network models for all observed regimes and RES integration scenarios indicate several security violations in Bulgarian power system. No violations have been



noted in referent RES scenario in any of the regimes as well as in Max Load regime in highn RES scenario. Security violations have been noted in the following cases:

- In high RES scenario, in Max SPP and Max SPP+WPP regime, 400 kV tie line between Romania and Bulgaria, Kozloduy – Tantareni circuit 1 is already highly loaded in referent RES scenario (94% for Max SPP and 70% for Max SPP+WPP). Consequently, several contingencies cause overloading of the mentioned line, of up to 120% for Max SPP and 104% for Max SPP+WPP. However, second parallel circuit of this tie line is out of operation in the observed network state. In cases of high exchange of power between Romania and Bulgaria, second circuit Kozloduy – Tantareni circuit 2 should be put into service which would resolve the identified security violation. It is important to mention that both circuits have different ratings observed from Bulgarian (1310 MVA) and Romanian (1188.5 MVA) side.
- In high RES scenario in Max SPP+WPP regime, 400 kV lines **C. Mogila Sofia** circuit 1&2 are both highly loaded (59%) which causes overloading of one circuit (103%) when the other is out of operation. This is caused by high export of power from Bulgaria towards North Macedonia and Greece caused by high RES generation in the observed regime.

## V.3.3 Georgia

Main results obtained from market simulations for all three relevant regimes for the power system of Georgia are given in the following tables.

CE	Max load		Max	SPP	Max WPP + SPP	
GE	Ref	High	Ref	High	Ref	High
Load	3652.1	3652.1	3251.3	3251.3	2383.1	2383.1
Generation	3882	4435	5695	5639	3985	5727
Losses	125.9	117.7	171.7	195.2	96.9	237.7
Desired interchange	104	657	2272	2216	1505	3247

#### Table 19 Totals - Georgia

Table 20 Generation per technology - Georgia

	Generation (MW)								
GE	Max load		Max SPP		Max WPP + SPP				
	Ref	High	Ref	High	Ref	High			
RoR	760	760	2345	2318	1658	1658			
Storage	2004	2485	2800	2077	409	425			
ТРР	1040	1040	0	0	413	55			
SPP	0	0	324	931	335	1339			



 WPP
 78
 150
 226
 312
 1170
 2250

Specific locations of renewables are not defined for the Georgian power system. Because of this, negative loads have been created in all 110 kV nodes, and total RES generation is then equally divided between the 110 kV nodes in order to achieve desired levels of RES generation, determined in market simulations. In such manner, load is equally reduced throughout the system enabling analyses of high RES integration to be performed.

Main characteristics of the observed regimes are the following:

- Max load is the regime with the highest consumption, which is mostly supplied from hydropower plants and the least from renewable sources. Due to the increase in production from wind and hydropower plants in the high RES scenario, there is a slight reduction in network losses.
- In Max SPP regime, most of the consumption is still covered by hydropower plants, while the increased production of solar and wind power plants eliminates the need for power generated from thermal power plants.
- Significant amount of power generated from solar and wind capacities in Max SPP + WPP regime in high RES scenario and consequently high export from Georgian power system, cause major increase of network losses in the system. However, due to the manner in which RES has been modeled in the system, this value would probably change if the exact locations of RES sources would be defined.

Load flow analyses performed on network models for observed scenarios indicate several voltage violations given in the following tables. These violations have been observed in initial models, as well as in both referent RES and high RES scenarios indicating that level of RES integration has no significant impact on the observed voltage violations.

Bus Number			Max	load		
	Bus Name	Ref	Res	High Res		
		Voltage [p. u.]	Voltage [kV]	Voltage [p. u.]	Voltage [kV]	
620945	TKVARCHELI	0.8666	190.66	0.8701	191.43	
620950	SOKHUMI	0.7727	170	0.7769	170.92	
620955	BZIFI	0.7185	158.07	0.7231	159.08	

Table 21	Voltage	violations	_	Max	load	reaime
	vonuge	VIOIALIONIS		I IUA	iouu	reginte



Bus Number		Max SPP					
	Bus Name	Ref	Res	High Res			
		Voltage [p. u.]	Voltage [kV]	Voltage [p. u.]	Voltage [kV]		
620950	SOKHUMI	0.8809	193.79	0.8506	187.14		
620955	BZIFI	0.8457	186.06	0.8138	179.04		

#### Table 22 Voltage violations - Max SPP regime

Tahle	23	Voltage	violations	_	Max S	'PP	+	WPP
Table	25	vonage	violations		rax	FF	7	VVFF

Bus Number			Max WP	P + SPP		
	Bus Name	Ref	Res	High Res		
	Duo Haine	Voltage [p. u.]	Voltage [kV]	Voltage [p. u.]	Voltage [kV]	
620955	BZIFI	within limits		0.8879	195.34	

Additionally, following loading violations are observed in Max SPP+WPP in high RES scenario.

Table 24 Loading violations - Max SPP + WPP regime

Branch name	Rate [MVA]	Max WPP + SPP				
		Ref Res		High Res		
		Loading [MVA]	Loading [%]	Loading [MVA]	Loading [%]	
220 kV TELAVI - GURJAANI	200	below limit		204.8	102.4	
220 kV QSANI - JINVALI	227	below limit		240.2	105.8	

In the Max WPP+SPP regime, simulated RES generation in 110 kV substations **Udzilauri**, **Jinvali**, **Barisaxo** and **Hkada** causes power to flow towards 220 kV network which is followed by overloading of 220 kV line **Jinvali** – **Qsani** (106%). Similarly, RES generation in 110 kV substations **Khadori**, **Samyuri**, **Akhmeta**, **Telavai** network causes power to flow towards 220 kV network causing overloading of 220 kV line **Telavi** – **Gurajaani**.

Overview of the voltage and loading conditions in the system is given in the following figures. In general, it can be observed that high RES integration causes higher element loadings which, consequently, causes slight drop in voltages and increase in network losses.





Figure 29 Overview of voltages - Georgia



Figure 30 Overview of loadings – Georgia

Contingency analyses performed on network models for all observed operating regimes show no security violations apart from mentioned overloadings observed in base case.

In general, locations of RES generation for high RES integration scenarios should be defined and modeled in detail in order to establish precise results of network state in such cases. This would be necessary in order to determine potential network weak spots and bottlenecks, enabling assessment of required network reinforcements to be considered.



Finally, precise reactive power capabilities of the RES generating units should be considered in order to improve voltage regulation conditions and subsequently overall network security and flexibility.

### V.3.4 Moldova

Overview of network totals as well as generation per each type of technology (fuel) for observed regimes is given in the following tables.

MD	Max load		Max	SPP	Max WPP + SPP		
	Ref	High	Ref	High	Ref	High	
Load	1101.4	1101.4	855.1	855.1	689	689	
Generation	1773	1795	617	657	768	953	
Losses	26.6	26.1	29.9	32.5	40.5	78	
Desired interchange	645	667	-268	-228	44	229	

### Table 25 Totals - Moldova

#### Table 26 Generation per technology - Moldova

	Generation (MW)								
MD	Max load		Max	SPP	Max WPP + SPP				
	Ref	High	Ref	High	Ref	High			
RoR	33	33	30	30	34	34			
СНР	169	169	0	0	0	0			
ТРР	1520	1520	360	304	304	304			
SPP	0	0	78	111	82	118			
WPP	51	73	149	212	348	497			

Some of the power generating units in the power system of Moldova are modeled as negative loads, defined according to results of market simulations. Renewables generation has been distributed proportionally to installed capacities found in the referent models.

Main characteristics of the observed regimes are the following:

- The Max load regime is the regime with both the highest export and consumption which is mostly supplied from thermal power plants.
- As for the Max SPP regime and Max SPP + WPP, the need for power generated from thermal power plants is greatly reduced due to the high integration of solar and wind capacities.
- In Max SPP + WPP regime, export is increased due to high RES generation, causing significant increase of 93% of losses in the system.



Overview of the voltages and loadings in the system is shown on the following tables. The most significant difference between referent and high RES scenario can be noticed in Max WPP + SPP regime, caused by high levels of generated power followed by decrease of overall voltages and increas of loading of elements.



Figure 31 Overview of voltages – Moldova



Figure 32 Overview of loadings - Moldova

Contingency analysis indicated possible voltage violations in the power system of Moldova. However, this is due to modeling of some of the generating units in the system. Specifically, when modeled as negative loads, generating units have no ability to regulate voltage and reactive power



generation/consumption and are observed as constant PQ nodes. Consequently, voltages may not be realistic, since no regulation is possible in cases of contingencies.

It is highly recommended to model power generating units as machines, since voltage setpoint can then be defined and maintained at selected values, enabling better and more realistic voltage conditions.

## V.3.5 Romania

Totals obtained in market simulations which are implemented in the network models and generation per technology (fuel) for the Romanian power system is given in the following tables.

RO	Max load		Max	SPP	Max WPP + SPP		
	Ref	High	Ref	High	Ref	High	
Load	9311.8	9311.8	7425.8	7425.8	7281	7281	
Generation	12708	12870	6898	7162	7638	9233	
Losses	419.2	332.4	302.2	431.2	159	227	
Desired interchange	2977	3139	-830	-566	198	1793	

#### Table 27 Totals - Romania

#### Table 28 Generation per technology - Romania

	Generation (MW)								
RO	Max load		Max	SPP	Max WPP + SPP				
	Ref	High	Ref	High	Ref	High			
RoR	1010	1010	1444	1444	1172	1172			
Storage	3386	3386	310	0	0	0			
ТРР	5594	5594	3191	2283	2577	2227			
Nuclear	1965	1965	0	0	0	0			
SPP	0	0	1674	3097	1749	3236			
WPP	753	914	278	337	2139	2597			

In Romanian network model, renewables are modeled as machines and total RES generation obtained from market analyses is distributed between units proportionally to maximum defined power (installed capacities).

Main characteristics of the observed regimes are the following:

• In Max load regime, additional wind capacities in the high RES scenario causes reduction of network losses compared to referent RES scenario at level of 21%.



- In Max SPP regime, Romania is importing power despite high generation from solar power plants, which is almost double in high RES scenario compared to referent RES scenario.
- In Max WPP + SPP regime, high generation from both wind and solar power plants cause increased export of power, which is 9 times higher in high RES compared to referent RES scenario. Increase in export matches increase in solar generation.

As previously mentioned, in Max load regime losses are reduced 21% in high RES scenario compared to referent RES. In both Max SPP and Max SPP + WPP losses are increased 43% in cases of higher RES integration.

Load flow analyses performed on network models for observed scenarios show two loading violations that occur in Max SPP high RES scenario.

Branch name		Max SPP				
	Rate	Ref Res		High Res		
	[MVA]	Loading [MVA]	Loading [%]	Loading [MVA]	Loading [%]	
400 kV Kozloduy - Tantareni	1188.5	below limit		1242.7	104.6	
220 kV Slatina - Gradiste	285.1	below limit		306.6	107.5	

Table	29	Loadina	violations	_	Max SPP
abic	~ ~	Louung	Violationis		i iux oi i

Tie line 400 kV **Kozloduy - Tantareni circuit 1** between Bulgaria and Romania is highly loaded because of high power exchange (1500 MW from Romania to Bulgaria) in the observed scenario. However, second existing parallel circuit of this tie line is out of operation in the observed network state. In cases of high exchange of power between Romania and Bulgaria, second circuit **Kozloduy – Tantareni circuit 2** should be put into service in order to maintain secure network operating conditions. It is important to mention that both circuits have different ratings observed from Bulgarian (1310 MVA) and Romanian (1188.5 MVA) side.

Additionally, 220 kV line **Slatina – Gradiste** is highly loaded (107.5%) due to high generation of power from SPP in SS **Gradiste** and TPP Isalnita, which supply load in 220 kV SS **Slatina** and flows towards 400 kV voltage level.

Overview of the overall voltage conditions and loading in the system is given in the following diagrams, indicating expected increase of loading of elements and subsequent drop of voltages in high RES integration scenarios compared to referent RES scenarios.





Figure 33 Overview of voltages - Romania



Figure 34 Overview of loadings - Romania

Contingency analyses performed on the observed network scenarios indicate several security violations:

In Max load regime, in both referent and high RES scenarios, HPP Retezat is operating at full capacity (350 MW). In case of outage of 220 kV line Hasdat - Pestis, overloading is observed on 220 kV Hasdat – Mintia of 112.4% in referent RES and 102.3% in high RES scenario. In case of outage of 220 kV line Hasdat – Mintia, 220 kV line Hasdat - Pestis is overloaded – 116.5% in referent RES and 106.1% in high RES scenario.



- In Max load regime, in both referent and high RES scenarios, HPPs Lotru, Malaia and Bradisor are operating at high capacity (628 MW) causing loading of 220 kV lines Lotru Sobiu circuit 1 and 220 kV line Lotru Sobiu circuit 2 of around 70% each in referent RES and high RES scenarios. Consequently, outage of one of the lines causes overloading of the second line of up to 150%.
- In Max SPP regime, both referent RES and high RES scenario, TPP Isalnita operates at high capacity (582 MW), causing high loading of 220 kV lines Isalnita A Gradiste, Isalnita A Craiova Nord circuit 1 and Isalnita A Craiova circuit 2 of around 74% percent each. Outage of 220 kV line Isalnita A Gradiste, causes overloading on both 220 kV circuits Isalnita A Craiova Nord lines of around 105% in referent RES and 109% in high RES scenarios. Also, outage of one circuit of 220 kV line Isalnita A Craiova Nord causes overloading of the second circuit of 127% in referent RES and 133% in high RES scenario.+
- In Max SPP+WPP regime, 220 kV line Slatina Gradiste is loaded 60% in referent RES and 86% in high RES scenario. Consequently, outage of 220 kV line Slatina Craiova circuit
   2 causes overloading of 107% in referent RES and 145% in high RES scenario of 220 kV Slatina Gradiste line.

In the observed regimes, internal 220 kV lines are highly loaded, mostly due to high generation from power plants, causing several loading violations. However, results show that there are just a few critical elements in Romania and that in all cases, problems exist already in referent RES scenario. It should be also noted that in some cases, violations are even relieved in high RES scenario, which points to the fact that observed critical elements are not new to the network operator or just provoked by additional RES capacities. In this kind of situations, when there are problems with evacuation of the generation, causing issues in the system, it is recommended to direct generation towards higher voltage level (400 kV). This improves security conditions and reduces losses in the system. In some cases, the solution could be proper topological changes, or, in other cases, upgrade of existing substations to higher voltage levels is recommended.

## V.3.6 Ukraine

Results obtained from market simulations for selected timestamps which are applied to regional network models are given in the following tables.

UA	Max load		Max	SPP	Max WPP + SPP		
	Ref	High	Ref	High	Ref	High	
Load	25290.7	25290.7	17853.5	17853.5	16760.9	16760.9	
Generation	23642	23724	15692	18373	19834	20250	
Losses	910.3	927.4	515.5	434.6	489.1	820.5	

#### Table 30 Totals - Ukraine



Desired interchange         -2559         -2477         -2677         4         2584         300	000
---	-----

			Generati	on (MW)		
UA	Мах	load	Max	SPP	Max WPP + SPP	
	Ref	High	Ref	High	Ref	High
RoR	31	31	37	37	15	15
Storage	4217	4261	0	0	0	0
Pump storage	1296	1296	0	0	0	-3414
ТРР	1492	1492	318	318	318	318
СНР	2960	2960	780	660	816	816
Nuclear	13132	13132	8374	8374	9895	9598
Biomass	440	440	440	440	440	440
SPP	0	0	4616	6840	4875	7224
WPP	74	112	1128	1705	3476	5254

#### Table 31 Generation per technology - Ukraine

Renewables are modeled as negative loads in the Ukrainian power system and summed RES generation obtained from market analyses is divided proportionally to values found in referent models.

Main characteristics of the observed regimes are the following:

- In Max load regime, the generation from renewable sources is at a minimum level and due to maximum load demand, loading of elements on a higher level, causing significant losses in the system, which are similar in both referent RES and high RES scenarios.
- In Max SPP regime, higher integration of solar power plants reduces the need for generation from thermal and nuclear power plants leading to increase of balance of the country, as well as decreased network losses in high RES compared to referent RES scenario.
- In Max WPP + SPP regime, increased production of solar and wind power plants in high RES scenario lead to significant export of power, as well as activation of pump storage facilities.

In Max load regime, losses in the system remain almost the same in high RES, as in referent RES scenario. In Max SPP, high solar generation causes decrease of import of power, reducing the losses 16% in high RES compared to referent RES scenario. In Max SPP + WPP scenario, however, losses are increased 68% due to significantly higher generation from renewables in high RES scenario and higher export.



Overview of the minimum, average and maximum voltage values, as well as maximum and average loading of elements is given in the following figures.



Figure 35: Overview of voltages – Ukraine



Figure 36: Overview of loadings - Ukraine



Voltages in the system are only slightly changed in all regimes, while loading of elements is reduced in Max load and Max SPP and increased in Max SPP+WPP when referent and high RES scenarios are compared.

No security violations are identified as a result of contingency analyses performed.

## V.3.7 Turkey

Overview of overall load, generation, losses and balance as well as generation per each type of technology (fuel) for power system of Turkey is given in the following tables.

TR	Max load		Max SPP		Max WPP + SPP		
	Ref	High	Ref	High	Ref	High	
Load	56060	56060	53545	53545	50973.2	50973.2	
Generation	54748	54748	52625	52625	49019	49019	
Losses	1648	1507	2040	1392.7	1005.8	861.6	
Desired interchange	-2960	-2960	-2960	-2960	-2960	-2960	

### Table: 32 Totals - Turkey

### Table 33: Generation per technology - Turkey

	Generation (MW)							
TR	Max load		Max SPP		Max WPP + SPP			
	Ref	High	Ref	High	Ref	High		
RoR	3124	3124	4902	4902	2064	2064		
Storage	14834	13926	15898	12633	8529	5986		
ТРР	30812	31587	13839	15024	13839	13839		
Nuclear	4440	4440	3264	3264	3264	3264		
SPP	0	0	12824	14740	11161	12829		
WPP	1538	1671	1898	2062	10162	11037		

Wind power plants in the Turkish power system are modeled as machines, so total generation obtained from market analyses is distributed between units proportionally to power generated in referent models. On the other hand, no specific locations were defined for solar generation, so overall load demand in the system was decreased for the amount of solar generation in the corresponding regimes.

Key characteristics of the observed regimes are the following:



- Turkey is importing power in all observed regimes.
- In Max load regime, majority of power is supplied from thermal power plants and hydro power plants.
- In Max SPP, significant amount of solar power is generated, reducing operation of thermal power plants by around 50%.
- In Max SPP+WPP, both solar and wind power plants are operating at a high capacity, covering 42% in referent RES and 47% in high RES, of total load.

In all observed regimes, losses in the system are reduced in high RES scenario, compared to referent RES scenario - Max load regime – 8%, Max SPP regime - 32% and Max SPP+WPP – 14%.

Overview of the minimum, average and maximum voltage values, as well as maximum and average loading of elements is given in the following figures.



Figure 37: Overview of voltages – Turkey





Figure 38: Overview of loadings – Turkey

Load flow analysis indicate slight decrease of loading in high RES scenarios of Max SPP and Max WPP compared to referent RES, which is followed by slight increase of voltages in the system. In Max load regime, no significant differences appear.

Contingency analyses performed on Turkish network for all analyzed regimes indicate several security violations:

- In Max load regime, in both referent RES and high RES scenarios, contingency of 400 kV line Kartal – Yeni DGKCS causes overloading of 125% of 400 kV line Kucukbakkalkoy – Umraniye which is already highly loaded (82%) in base case.
- In Max SPP regime, referent RES scenario 400 kV line Adapazari Izmit is highly loaded (97%) and consequently, multiple contingencies cause overloading of the mentioned line, most significant being the overloading of 125% in case of contingency of 400 kV line Adapazari Tepeoren. In high RES integration scenario, loading of 400 kV line Adapazari Izmit is reduced to 81% in base case, which causes reduction of number of contingency violation issues to one. In case of the mentioned outage 400 kV line Adapazari Tepeoren, loading of the Adapazari Izmit is slightly above upper limit 104.5%.
- Additionally in Max SPP regime, referent RES scenario, 400 kV line Kursunlu Kayabasi is loaded 87% in base case which is followed by two overloadings: 112% in case of contingency of 400 kV line Baglum Cankiri Kayabasi and 106% in case of contingency of 400 kV line Kursunlu Boyabat. As in previous case, loading of 400 kV line Kursunlu Kayabasi is reduced in case of high RES integration scenario, eliminating all contingency violations.
- In the same scenario, contingency of 400 kV line Resadiye Kose, causes overloading of 107% of 400 kV line Altinordu – Tirebolu, which is also resolved in high RES integration scenario.


In general, lower loading of the elements, followed by minimization of contingency violations in high RES scenario is due to the fact that solar generation in Turkey is modeled by reduction of total load in the system, which causes lower loadings of lines throughout the system, especially in Max SPP, high RES scenario.

However, in order to mitigate identified security violations, different measures should be analysed. In general, non-costly remedial actions in terms of topological changes in the network are often sufficient to reduce potential overloadings. Most often used non-costly remedial actions are switching on/off of lines and busbar couplers, adjustment of taps on power transformers or phase shifters and bus shunts commissioning. If no such remedial actions are identified as sufficient, costly measures must be taken into account, ranging from curtailment of RES to load shedding in more extreme cases.



### V.4 Regional Summary

In general, high RES integration in the Black Sea Region causes no significant issues in the transmission network. In several cases, security violations that exist in the high voltage network in referent RES scenario are resolved by integration of high RES capacities at lower voltage levels, by relieving loading of elements caused by conventional flow of power from higher towards lower voltage levels.

Load flow simulations performed on updated network models indicate almost no violations of operational security limits in terms of voltages outside of permissible limits or overloading of elements for all countries. There are some violations in Georgia, Romania and Turkey.

In case of Georgia, some voltage violations and overloadings have been observed, but majority of them already exist in initial models and are not provoked by increase of RES capacities. Only in the Max WPP+SPP regime in high RES scenario, there is an overloading of 220 kV line **Jinvali – Qsani** (106%) and 220 kV line **Telavi – Gurajaani** (102%) with undervoltages in SS Bzifi (89%).

In case of Romania, 220 kV line **Slatina – Gradiste** is highly loaded (107.5%) in high RES scenario in Max SPP regime, due to high generation of power from SPP in SS **Gradiste** and TPP Isalnita, which supply load in 220 kV SS **Slatina** and flows towards 400 kV voltage level. Contingency analyses performed on the observed network scenarios indicate several security violations.

In the observed regimes, internal 220 kV lines are highly loaded, mostly due to high generation from power plants, causing several loading violations. However, results show that there are just a few critical elements in Romania and that in all cases, problems exist already in referent RES scenario. It should be also noted that in some cases, violations are even relieved in high RES scenario, which points to the fact that observed critical elements are not new to the network operator or just provoked by additional RES capacities. In this kind of situations, when there are problems with evacuation of the generation, causing issues in the system, it is recommended to direct generation towards higher voltage level (400 kV). This improves security conditions and reduces losses in the system. In some cases, the solution could be proper topological changes, or, in other cases, upgrade of existing substations to higher voltage levels is recommended.

In case of Turkey, contingency analyses indicated several security violations in 400 kV network. In almost all cases, violations are lower in high RES scenario due to the fact that solar generation in Turkey is modeled by reduction of total load in the system, which causes lower loadings of lines throughout the system, especially in Max SPP, high RES scenario.

However, in order to mitigate identified security violations, different measures should be analysed. In general, non-costly remedial actions in terms of topological changes in the network are often sufficient to reduce potential overloadings. Most often used non-costly remedial actions are switching on/off of lines and busbar couplers, adjustment of taps on power transformers or phase shifters and bus shunts commissioning. If no such remedial actions are identified as sufficient, costly measures



must be taken into account, ranging from curtailment of RES to load shedding in more extreme cases.

Concerning the losses, summary for all analysed countries is presented in Table 34 and in Figure 39.

	Losses (MW)							
Country	Max load		Max SPP		Max WPP + SPP			
	Ref	High	Ref	High	Ref	High		
AM	40.4	37	46.7	59.2	54	41.8		
BG	173.6	182.7	99.7	122.3	182.3	234.8		
GE	125.9	117.7	171.7	195.2	96.9	237.7		
MD	26.6	26.1	29.9	32.5	40.5	78		
RO	419.2	332.4	302.2	431.2	159	227		
UA	910.3	927.4	515.5	434.6	489.1	820.5		
TR	1648	1507	2040	1392.7	1005.8	861.6		
BSTP	3344	3130.3	3205.7	2667.7	2027.6	2501.4		

### Table 34: Losses per country



Figure 39: Losses in all regimes in all countries

In almost all countries, additional RES generation leads to increase in losses, except in Turkey where losses decrease has been detected in all regimes. The difference in losses is the lowest in Max load regime where RES generation is lower than in Max SPP and Max WPP+SPP regimes. In different regimes with Max SPP or Max WPP+SPP, countries also change their balance positions which provokes bigger changes in losses.

It should be also noted, that, for most countries, higher RES generation leads to increase of export.



# **VI. CONCLUSIONS**

This study should help Black Sea TSOs better prepare for future large-scale RES integration and anticipate the expected changes in network and market operations that will take place as cross-border transactions and markets open up region wide.

The study addressed both how electricity markets and prices will be affected by substantial amounts of RES development, and how the transmission grid will need to adapt – both within the BSTP countries and between them – as RES becomes a more significant share of the generation mix by 2030.

The study results refer to the year 2030, with market analyses that included hourly simulations of the power system with subsequent results for each hour of the year and network analysis focused on snapshots at moments of network stress.

### In Table 35 main results of Antares simulations are presented.

#### Table 35: Main system operating indicators for the BSTP region in 2030 – ref. RES vs high RES

Country	Scenario	RES (wind+solar) capacities (MW)	RES (wind+solar) capacities (GWh)	Consumption (GWh)	Generation (GWh)	Spillages (GWh)	Net interchange (GWh)	Prices (\$/MWh)
АМ	Ref	1,020	1,574	7,730	10,910	142	3,180	33.7
	High	1,250	1,936	7,730	10,003	432	2,273	22.7
BG	Ref	3,816	5,531	36,986	42,308	0	5,322	57.8
	High	4,770	6,914	37,076	43,098	0	6,022	55.9
GE	Ref	1,850	5,543	23,518	33,044	1,346	9,526	34.6
	High	4,700	12,369	23,822	36,783	3,373	12,961	23.1
MD	Ref	861	1,530	6,879	5,779	0	-1,100	57.8
	High	1,230	2,185	6,879	6,101	0	-778	54.9
RO	Ref	6,200	13,399	63,316	73,830	0	10,514	56.4
	High	8,800	18,406	63,316	76,049	0	12,733	54.1
UA	Ref	12,267	20,968	169,624	150,828	0	-18,796	62
	High	18,310	31,429	170,619	159,553	0	-11,066	56.8
TR	Ref	35,815	75,591	412,871	388,516	19	-24,355	70.6
	High	40,000	83,833	412,871	388,999	77	-23,872	69.2
BSTP	Ref	61,829	124,135	720,924	705,215	1,507	-15,709	53.3
	High	79,060	157,072	722,313	720,586	3,882	-1,727	48.1

Main conclusions based on the results of market simulations are as follows:



- Main technology in 2030 in BSTP region is nuclear technology (due to high nuclear generation in Ukraine) and it supplies more than 23% of the BSTP load. At similar levels there are hydro and gas technologies (21% and 18%), mainly due to high participation of these technologies in Turkish generation mix.
- RES generation (Wind + Solar) is also at similar level 17% and 22% of the BSTP demand is supplied by RES technologies in 2030 which can be considered as high. Together with generation from hydro power plants, "green" energy supplies more than 40% of the regional demand.



Figure 40: BSTP generation mix in 2030 - ref. RES vs high RES



Figure 41: Main system operating indicators for the BSTP region in 2030 – ref. RES vs high RES



- As one of the main consequences of increased RES generation, TPPs generation falls, from 215 TWh to around 199 TWh (- 16 TWh). Decrease in TPPs generation is equally divided between gas and lignite/coal technologies pointing to the fact that all fossil fuel technologies will have reduced profitability.
- Together with decrease of fossil fuel fired TPPs generation, CO2 emission decrease from 139.2 mil.T to 130.7 mil.T (-6%).
- Considering that the region as a whole is importer, additional generation from RES will decrease the net import from 15.7 TWh to 1.7 TWh (-89%). Higher RES generation provokes decrease of TPPs generation but at the smaller level, and this leads to decrease of the net import. Changes in balance positions for all countries (Figure 41) shows that in almost all countries, due to additional RES generation, export is increased or import is decreased. The only different behavior can be seen in Armenia. The reason for this lies in extreme increase in RES generation in Georgia which push down thermal generation in Armenia and decreases its net export.



Figure 42: Balance positions per countries in 2030 - ref. RES vs high RES

• At the same time, higher RES generation leads to lower prices, due to the fact that cheaper power plants become marginal. The average annual price in BSTP region as a whole will fall from 53.3 \$/MWh to 48.1 \$/MWh (-10%).





Figure 43: Average annual prices per BSTP country in 2030: ref. RES vs high RES

- BSTP countries are grouped in 3 price zones:
  - Armenia and Georgia (around 25-35\$/MWh); Armenia and Georgia have lower prices than the central part of the BSTP region due to cheaper gas (and non-CO2 taxes) and excess of HPPs and RES generation
  - Bulgaria, Moldova, Romania and Ukraine (around 55\$/MWh-60\$/MWh) and
  - Turkey (around 70 \$/MWh), since it is a big importing market zone.
- Regarding the decrease in prices, Armenia and Georgia will have the largest decrease (around 35%) mainly due to increased spillages. Having in mind that both countries are exporters, this could decrease benefits from energy trade. This big decrease in wholesale market prices may seriously endanger business environment for the thermal plants in both countries.
- In Armenia and Georgia higher RES generation will lead to increased spillages, due to the fact that in some hours generation is greater than consumption, cross border lines are congested and technical limitation of power plants don't allow a further decrease of generation. During these hours, part of RES generation has to be curtailed. With high RES generation, spillages in Armenia rise from 0.1 TWh to 0.4 TWh while in Georgia this increase is extreme: from 1.3 TWh to 3.3 TWh. Having in mind that these spillages present a big part of the RES and total generation of these countries, further investigations related to acceptable levels of RES capacities and introduction of flexibility levers are advised.
- In case of Ukraine and Turkey, high RES integration and prices decrease could have a positive impact on wholesale market and energy trade. However, maybe more interesting are expected changes in these power systems from today till 2030:
  - In case of Ukraine, large scale decommissioning of coal TPPs is envisaged till 2030 which will drastically change generation mix and balance: coal-fired TPPs generation will drop from around 50 TWh in 2017 to around 3.5 TWh in 2030. This drop will be partially compensated (hopefully) by large scale RES generation which will rise from around 2 TWh (in 2017) to 20 TWh in referent and 31 TWh in high RES scenario, but



balance will be changed from +5 TWh in 2017 to -19 TWh in referent RES and -11 TWh in high RES scenario in 2030.

- In case of Turkey, expected consumption growth from 300 TWh to 412 TWh in 2030 will be hardly compensated with new HPPs, nuclear plants and rather high level of RES: +48 TWh in referent and + 56 TWh in high RES scenario, and Turkish import will increase from 2.7 TWh (2018) to 24 TWh.
- Having in mind that additional RES capacities, besides the needs for flexibility, also increase the needs for balancing reserve, we checked if the estimated required reserve (FCR+FRR) can be satisfied with unengaged capacity in TPPs and HPPs with storages. Results showed that in almost all countries, the required balancing reserve can be provided in all hours during the year in all analysed climatic years and hydrological conditions except:
  - In case of Georgia, where required balancing reserve of 390 MW cannot be satisfied in 65 and 56 hours during the year, in ref. and high RES scenarios respectively. Analyses showed that a lack of the balancing reserve can be expected practically only during the flooding season
  - In case of Romania, where required balancing reserve of 1400 MW cannot be satisfied in 251 and 230 hours in average, during the year, in ref. and high RES scenarios respectively. Analyses showed that lack of the balancing reserve can be expected in all seasons except in spring.

Concerning the network operation, in general, high RES integration in the Black Sea Region causes no significant issues in the transmission network. In several cases, security violations that already exist in the high voltage network in the referent RES scenario are resolved by the integration of more RES capacities at lower voltage levels and by relieving the loading of elements caused by the conventional flow of power from higher towards lower voltage levels.

In the observed regimes, problems have not been observed on tie lines, which is very important.

In just a few cases, security violations have been observed at internal lines (220 or 400 kV in Romania and Turkey) usually highly loaded, mostly due to the high generation from power plants. When there are problems with the evacuation of the generation, causing issues in the system, it is recommended to direct the generation towards a higher voltage level (400 kV). This improves security conditions and reduces losses in the system. In some cases, the solution could be proper topological changes, or, in other cases, the upgrade of existing substations to higher voltage levels is recommended.

The results of the analyses show that, for most countries, higher RES generation leads to an increase in the export of power. In order to enable evacuation of this amount of energy and avoid curtailment of RES capacities, strong interconnection and cross border mechanisms should be maintained.

In order to improve network flexibility and reliability, national Grid Codes should define all relevant requirements that newly connected RES power generating units should fulfill. This includes the provision of ancillary services such as balancing and frequency regulation, as well as voltage and



reactive power regulation which improves security and enables flexibility in achieving optimum network operation.

Finally, RES generating capacities should be integrated into the network models as precisely as possible, in order to provide operational and planning engineers with the possibility to precisely analyse perspective network states and identify any potential issues that may occur. This precise modeling includes both active and reactive power capabilities of the generating units to be defined in the network models which enables higher model flexibility, better convergence and more accurate results.

Also, set of the border nodes and status and parameters of tie lines should be defined in cooperation between neighboring TSOs in order to ensure that updated national grid models may be easily integrated into the regional grid model, enabling the latest network improvements to be included.



### **VII. REFERENCES**

- [1] "Identification of Appropriate Generation and System Adequacy Standards for the Internal Electricity Market"; EC, 2016
- [2] "Assessing resource adequacy in an integrated EU power system", Wind Europe, 2016
- [3] **"Zvit-z-otsinky-vidpovidnosti-dostatnosti-generuyuchyh-potuzhnostej**"; UKRENERGO, 2017
- [4] **"TYNDP\_GE-2019-2029\_ENG"**; GSE, 2019
- [5] **"MAF2019"**; ENTSO-E, 2019
- [6] **TYNDP 2018,** ENTSO-E, 2018
- [7] **TYNDP 2018,** ENTSO-E, 2018
- [8] IEA "Current Policies", World Energy Outlook 2015



# **TABLE OF FIGURES**

Figure 1: Envisaged growth of installed RES capacities and their share in the BSTP region	5
Figure 2: Study methodology approach	11
Figure 3: Market scenarios analysed in the Study	13
Figure 4: Market simulations results	13
Figure 5: Network regimes analysed in the Study	14
Figure 6: Consumption growth rates	24
Figure 7: Monthly energy consumption (GWh) for 2030 – Armenia	27
Figure 8: Generation mix of Armenia in 2030 – ref. RES vs high RES	28
Figure 9: Main system operating indicators in Armenia in 2030 – ref. RES vs high RES	29
Figure 10: Generation mix of Bulgaria in 2030 - ref. RES vs high RES	30
Figure 11: Main system operating indicators in Bulgaria in 2030 – ref. RES vs high RES	32
Figure 12: Generation mix of Georgia in 2030 – ref. RES vs high RES	33
Figure 13: Main system operating indicators in Georgia in 2030 – ref. RES vs high RES	35
Figure 14: Generation mix of Moldova in 2030 – ref. RES vs high RES	36
Figure 15: Main system operating indicators in Moldova in 2030 – ref. RES vs high RES	37
Figure 16: Figure 16Generation mix of Romania in 2030 - ref. RES vs high RES	38
Figure 17: Main system operating indicators in Romania in 2030 – ref. RES vs high RES	39
Figure 18: Generation mix of Ukraine in 2030 - ref. RES vs high RES	40
Figure 19: Main system operating indicators in Ukraine in 2030 – ref. RES vs high RES	42
Figure 20: Generation mix of Turkey in 2030 - ref. RES vs high RES	43
Figure 21: Main system operating indicators in Turkey in 2030 – ref. RES vs high RES	44
Figure 22: BSTP generation mix in 2030 - ref. RES vs high RES	46
Figure 23: Main system operating indicators for the BSTP region in 2030 – ref. RES vs high RES.	47
Figure 24: Average annual prices per BSTP country in 2030: ref. RES vs high RES	48
Figure 25: Overview of voltages in Armenia	53
Figure 26: Overview of loadings in Armenia	53
Figure 27: Overview of voltages in Bulgaria	56
Figure 28: Overview of loadings in Bulgaria	56
Figure 29 Overview of voltages - Georgia	60
Figure 30 Overview of loadings – Georgia	60
Figure 31 Overview of voltages – Moldova	62
Figure 32 Overview of loadings - Moldova	62
Figure 33 Overview of voltages - Romania	65
Figure 34 Overview of loadings - Romania	65
Figure 35: Overview of voltages – Ukraine	68
Figure 36: Overview of loadings - Ukraine	68
Figure 37: Overview of voltages – Turkey	70
Figure 38: Overview of loadings – Turkey	71
Figure 39: Losses in all regimes in all countries	74
Figure 40: BSTP generation mix in 2030 - ref. RES vs high RES	76
Figure 41: Main system operating indicators for the BSTP region in 2030 – ref. RES vs high RES.	76
Figure 42: Balance positions per countries in 2030 - ref. RES vs high RES	77
Figure 43: Average annual prices per BSTP country in 2030: ref. RES vs high RES	78



# **TABLE OF TABLES**

Table 1: General technical and economic parameters for TPPs from TYNDP 2018 common base .	. 19
Table 2: Additional technical parameters for TPPs from TYNDP 2018 common base	. 19
Table 3: Fuel and CO <sub>2</sub> prices in 2030 from TYNDP 2020	. 20
Table 4: Average 2030 yearly price on external market	. 22
Table 5: Referent demand growth	. 23
Table 6: Installed wind power plant (WPP) capacities	. 24
Table 7: Installed solar power plant (SPP) capacities	. 25
Table 8: Installed hydro power plant (HPP) capacities	. 25
Table 9: Installed thermal power plant (TPP) capacities	. 26
Table 10: PS HPPs generation in Bulgaria	. 31
Table 11: PS HPP Enguri Generation	. 34
Table 12: PS HPPs Generation in Ukraine	. 41
Table 13: Main system operating indicators for the BSTP region in 2030 - ref. RES vs high RES	. 45
Table 14: Generation from WPPs and SPPs in selected regimes	. 51
Table 15: Totals - Armenia	. 52
Table 16: Generation per technology - Armenia	. 52
Table 17: Totals - Bulgaria	. 54
Table 18: Generation per technology - Bulgaria	. 55
Table 19 Totals - Georgia	. 57
Table 20 Generation per technology - Georgia	. 57
Table 21 Voltage violations - Max load regime	. 58
Table 22 Voltage violations - Max SPP regime	. 59
Table 23 Voltage violations - Max SPP + WPP	. 59
Table 24 Loading violations - Max SPP + WPP regime	. 59
Table 25 Totals - Moldova	. 61
Table 26 Generation per technology - Moldova	. 61
Table 27 Totals - Romania	. 63
Table 28 Generation per technology - Romania	. 63
Table 29 Loading violations - Max SPP	. 64
Table 30 Totals - Ukraine	. 66
Table 31 Generation per technology - Ukraine	. 67
Table: 32 Totals - Turkey	. 69
Table 33: Generation per technology - Turkey	. 69
Table 34: Losses per country	. 74
Table 35: Main system operating indicators for the BSTP region in 2030 - ref. RES vs high RES	. 75

