

Challenges of a Flexible Future:


Coal Generation as a Tool for Grid Flexibility and Stability

Mike Caravaggio
Senior Program Manager
July 23, 2019



Electric Power Research Institute's Mission

Advancing *safe, reliable, affordable* and *environmentally responsible* electricity for society through global collaboration, thought leadership and science & technology innovation



Agenda

- Implications of non-dispatchable power and need for flexibility
 - Duck Curves & Generation Supply Curves
 - The value propositions from flexibility
- The challenge of achieving flexible generation
 - Balancing the scales
 - Achieving safe, reliable, affordable, environmentally responsible electricity
 - EPRI Collaborative R&D

EPRI GENERATION SECTOR

Enabling Flexible Operations
of the Generation Fleet

<http://genstrategy.epri.com/enabling-flexible-operations-of-the-generation-fleet/>

Publicly available website



Publicly Available Reports

[3002015097](#)

2019 Description of Past EPRI Flexible Operation R&D Reports

>200 Reports

[3002007374](#)

2016 Flexibility White Paper

[3002005859](#)

2016 Changing Mission Study*

[3002006517](#)

2014 DOE Sponsored Flexibility Study

*Available only to EPRI Members but summarized in 2017 Power Engineering Article



[Power Engineering](#)

2017 Changing Mission Summary

Generating Technologies

Semi-Dispatchable:

- Solar Thermal
- Nuclear
- Hydroelectric



Dispatchable:

- Coal
- Gas
- Biomass




Non-Dispatchable:

- Wind
- Solar PV



Daily Electricity Demand



Demand and Supply must balance ... every second

Duck Curves


California Solar Photovoltaic

Flexibility – An Example from CAISO impact of Increasing Solar PV

Net Load: Actual Power Demand on the Grid, less the power provided by non-dispatchable generation (e.g. solar and wind)


CAISO – 2012 Actual Net Load Demand

Net load - March 31




CAISO – 2020 Modeled Net Load Demand

Net load - March 31




	2012 Actual	2020 Prediction	Implication
Baseload Demand	18,000 MW	12,000 MW	Lower minimum loads, more on/off operation
Peak Ramping Rate	~1000 MW per hour	>5000 MW per hour	Faster loading/unloading, brownout/blackout risk
Peak Demand	24,000 MW	26,000 MW	More installed dispatchable capacity required
Daily Total Energy	498,000 MWh	459,000 MWh	Fewer units of production across more capacity
Peak to Base	6,000 MW	14,000 MW	More flexible capacity required

Solar: Hourly Average Load – CAISO – April 23, 2017



<http://www.caiso.com/TodaysOutlook/Pages/default.aspx>



Flexibility due to Solar PV

- Daily Ramp
 - Minimum Loads, On/Off Cycling
 - Driven by low or even negative prices
 - Short duration extreme high prices
- Economic Viability Challenged
 - Increases Wear & Tear (Slopes / Min)
 - Still need dispatchable units (Max)
 - Reduced MWh by dispatchable units (Area)
 - Reduced price per MWh produce
 - Short duration high value periods of production

May 5, 2019
had a net
load hour
of **5,470**
MW

Daily Ramping / Minimum Load / Daily On-Off Cycling

May 5, 2019


- Energy Imbalance Market
 - Significant Import to Satisfy Ramp
 - Significant Export to Manage Excess
- Dispatchability Adjacent to Non-dispatchable Market has significant arbitrage value
- Value of incremental non-dispatchable power?

Ontario power: Why Ontario effectively paid its neighbours \$214,584.24 in one weekend hour to take our power

Ontario Sunda see Ni We're paying others to use our electricity - again

As most Ontarians slept on April 10, they unknowingly deposited a credit of almost \$229,000 in the accounts of electricity users in Quebec, New York and Michigan.

<https://communityimpact.com/austin/georgetown/city-county/2018/12/10/georgetown-will-renegotiate-renewable-contracts-after-energy-price-drop-costs-city-6-84-million/>



California Capacity Contracts

- 10-20+ year agreements for replacement units
- Storage and Gas Plants


	LA Basin	Big Creek/Ventura	Bay Area	Other PG&E Area	San Diego-IV	CAISO System
Contracted Capacity (MW)	83,851	26,500	70,150	29,877	24,300	76,239
Percentage of Total Capacity in Data Set	27%	9%	23%	10%	8%	25%
Weighted Average Price (\$/kW-month)	\$3.48	\$3.45	\$2.22	\$2.27	\$3.18	\$2.09

2017 Resource Adequacy <https://www.cpuc.ca.gov/General.aspx?id=6307>

TABLE 2: LARGE SCALE REPLACEMENTS FOR CAISO JURISDICTIONAL OTC UNITS AND SAN ONOFRE

Resource Name	Capacity (MW)	Location	Commercial Online Date	Contract Duration (Years)
Alamitos Energy Center	640	LA Basin	2020	20
Alamitos Energy Storage	100	LA Basin	2021	20
Barre Wellhead	98	LA Basin	2020	20
Carlsbad Energy Center	500	San Diego	2018	20
Huntington Beach Energy Center	644	LA Basin	2020	20
Pio Pico Energy Center	300	San Diego	2017	25

- At \$2.20-\$3.50/kW-month
- 500 MW – 12-20+Million / year



<https://www.cpuc.ca.gov/WorkArea/DownloadAsset.aspx?id=6442457193>

<http://www.neo.ne.gov/statshtml/204.htm>

Generation Supply Curve Texas Wind


Wind Energy Growth Texas Example: Texas Generation Supply Curve 2009 / 2016

2018 Wind Capacity
>22,000 MW




Generation Supply Curve - ERCOT: 2009

Capacity Technology Adjustments: Combined Cycle - 100%; Combustion Turbine - 100%; Hydraulic Turbine - 100%; Internal Combustion - 100%; Nuclear - 100%; Pump Storage - 100%; Steam Turbine - 100%; Wind Turbine - 100%; Other - 100%; Geothermal - 100%; Solar - 100%;
Capacity Status Adjustments: Announced - 100%; Early Development - 100%; Advanced Development - 100%; Under Construction - 100%;



Generation Supply Curve - ERCOT: 2016

Capacity Technology Adjustments: Combined Cycle - 100%; Combustion Turbine - 100%; Hydraulic Turbine - 100%; Internal Combustion - 100%; Nuclear - 100%; Pump Storage - 100%; Steam Turbine - 100%; Wind Turbine - 100%; Other - 100%; Geothermal - 100%; Solar - 100%;
Capacity Status Adjustments: Announced - 100%; Early Development - 100%; Advanced Development - 100%; Under Construction - 100%;




● Solar
 ● Wind
 ● Other Fuel
 ● Biomass
 ● Coal
 ● Water
 ● Natural Gas
 ● Uranium

..... Min Load
 ——— Average Load
 - - - Peak Load

www.snli.com

Texas Coal Fired Unit


2002 MCR 594 MW, 71.9% CF, 83% Op. CF



ENERGY OCT 13
Texas' largest power generator speeds up coal's decline with closure of two more plants



2016 MCR 563 MW, 41.6% CF, 70% Op. CF



Extended Layup / Minimum Load / Load Following

Implications of Over Supply

Variable Generation Drives Fundamental Change

Rapid growth in variable generation is driving the need for a more flexible power system and for a research and development strategy to help achieve that.

In most cases, variable generation is connected to the grid, benefitting support, flexibility, and integrated with the

Ontario power: Why Ontario effectively paid its neighbours \$214,584.24 in one weekend hour to take our power

Ontario's Sunday. E see Niagara

Ontarians paid \$37 billion extra for electricity from general Bonni

Fri., July 13, 2018

Ontario's new Progressive Conservative government is pulling the plug on 758 green energy contracts in a bid to save \$790 million.

► A way of snaring the cost of going green, government says

The New York Times

ENERGY & ENVIRONMENT

A Texas Utility Offers a Nighttime Special: Free Electricity

By CLIFFORD KRAUSS and DIANE CARDWELL NOV. 8, 2015

News / Queen's Park

Ontario paying for wind turbines to not produce electricity

an operator can now order wind them not to produce electricity when it's

'Unprecedented': Energy operator in daily fight to keep lights on

By Cole Latimer

April 4, 2019 – 12.04am

Australian Energy Market Commission's (AEMC)

- Payments soar 13,733% in ONE year... and £1.6million is paid out on one day alone
- Cost of paying wind farms to close is ultimately passed onto families

OPER :37 GMT, 18 January 2012

Tweet +1 Share

View



farms in Pacific Northwest paid to reduce

Published March 07, 2012 • FoxNews.com 2717 715 61

Flexibility Required to Balance Non-Dispatchable Power

Flexible Assets Within Market with high penetration of non-dispatchable generation

- Ramp down / ramp up driven by negative operating margins
 - Daily cycle for solar
 - More variation for wind
- Potential for long periods of zero output
 - Generally more prevalent with wind in shoulder months for demand
- Potential for short periods of high wholesale prices
 - Daily very short periods for solar
 - Seasonal longer periods for wind
- Reduction in production units and in average price per unit - more challenging to cover fixed costs
- Pressure on both top line revenue and bottom line net income (wear & tear / complexity cost)
 - Capacity Contracts covering fixed costs have been used for replacement of long term dispatchable assets

Flexible Asset in Neighboring Market without high penetration of non-dispatchable generation




- Opportunity to import low cost, import free, or be paid to import and then resell in own market
- Opportunity to export at high price to satisfy high ramping needs of neighboring market
 - Top line growth can balance cost pressure of flexible operation

For Grid Stability – Need for Flexibility is increasing

Actual Value of Flexibility for Generating Company depends heavily on markets

What about Europe?

Energiewende (German for energy trans



/ no significant output

and nuclear at this time
i-dispatchable Generation

17

[78/electricity-prices-for-households-](https://www.electricitymap.org/78/electricity-prices-for-households-)

!

ation

35 Billion USD (~2.1% of GDP)

s would total

<https://www.electricitymap.org>

What about Storage?

Electricity production in Germany in January 2019

<https://www.energy-charts.de/power.htm?source=all-sources&year=2019&month=1>


date selection

year: 2019

month: January

week:

- conv. >100 MW
- all sources
- solar, wind
- import, export
- run-of-river
- nuclear
- lignite
- lignite per unit
- hard coal
- oil
- gas
- waste
- pumped storage
- wind offshore
- wind onshore



>1000 GWh of Storage needed – 10,000 100 MWh batteries


Coal Generation as a Tool for Grid Flexibility and Stability




“You can’t wipe out society and make a whole new society. You have to deal with the society that exists. But you have to figure out how you’re going to change it to something that’s better.”

Chauncey Starr, EPRI Founder

US Annual Electricity Capacity (source EIA)



US Annual Electricity Generation (source EIA)




Resource Reliability Contributions

EPRI whitepaper (2015):
Contributions of Supply & Demand Resources to Required System Reliability Services (3002006400)

WARNING: Relative rankings in table based on specific assumptions and disclaimers documented in white paper—do not use in isolation. Relative scores are based on “typical” capabilities of resources presently being installed.

		SYNCHRONOUS INTERCONNECTION					INVERTER-BASED INTERCONNECTION				DEMAND RESPONSE	
		Coal	Natural Gas Simple Cycle	Natural Gas Combined Cycle	Nuclear	Hydro	Grid Scale Wind	Grid Scale PV	Distributed PV	Distributed Battery Storage	Large (Industrial/Commercial)	Small (Aggregated)
Volt/Var Control		5	5	5	5	5	5	5	3	3	0	0
Short Circuit Contribution		5	5	5	5	5	3	3	3	3	0	0
Frequency Control	Inertial Response	5	3	5	5	5	3	0	0	0	3	0
	Primary Frequency Response (droop)	3	3	3	0	5	3	3	0	3	3	0
	Regulation	3	5	5	0	5	3	3	0	3	3	3
	Load Following/Ramping	3	5	5	0	3	3	3	0	3	3	3
	Spinning Reserve	3	5	5	0	5	3	3	3	3	5	5
Short-term Availability (fuel)		5	3	3	5	3	3	3	3	3	3	3
Long-term Availability (plant)		3	3	3	5	5	3	3	3	3	3	3
Black Start		3	3	3	0	5	0	0	0	0	0	0

Reliable system operation
 Synchronous Interco



- Must Ensure Reliability when considering new Resource Mix in Planning
- Not all Resources equal in Reliability Capability


Evaluating Flexibility – Typical Capabilities

Flexibility Parameters:


- On/Off, Upward/Downward Ramp, Minimum Load

	On/Off	Ramp Rate	Minimum Load
Coal (Subcritical)	Possible 2-5h lead time (Not typically done)	0.6-4%/minute (avg. 1%)	20-55% (avg. 38%)
Coal (Supercritical) Constant Pressure	Not done	0.6-4%/minute (avg. 1%)	40-70% (avg. 52%)
Coal (Supercritical) Sliding Pressure	Possible 2-5h lead time (Not typically done)	1-8%/minute	20-40%
Gas (Supercritical) Sliding Pressure	Possible 1-4h lead time	0.6-7%/minute	10-50%
Combined Cycle	Possible 1-4h lead time	0.8-15%/minute (avg. 3%)	40-70% (1x1 ~65%, 2x1 ~55%, 3x1 ~45%)
Simple Cycle	Possible 0.1-1h lead time	7-30%/minute (avg. 14%)	35-60%
Hydroelectric	Possible, <0.1h lead time	15-25%/minute	5-6%
Reciprocating Engines	Routinely done 0.1h lead time	25%/minute	Modular
U.S. Nuclear	Not done	Not done	60-80%

Example Fixed O&M Costs






Example Fixed O&M Costs




Dispatchable Asset Current State of Value and Cost

Value




Cost


Conventional Coal Fired Power Plant



Combined Cycle Gas Turbine (CCGT) Power Plant




EFOR Coal Units >100MW versus Annual Start Range



Minimize Negative Margins / Minimize Starts – Minimize Damage from Starts (Cost)

Reliable, Safe, Affordable, Environmentally Responsible Electricity



Understanding the Challenge



Flexibility and Overall Plant Reliability


Conventional Coal Fired Power Plant

Combined Cycle Gas Turbine (CCGT) Power Plant



Age and cycling (flexible operation) impacts plant reliability


Coal Fired Power Plant



Some General Impacts of Flexible Operation


Flexible Operation: Thermal Fatigue Damage

- Predominate failure mode in boiler and turbine components subjected to:
 - Frequent starts
 - Fast ramping
 - Load following
- Caused by:
 - Temperature mismatch between steam and metal surfaces
 - High amplitude stress cycles result
 - Rapid cooling caused by liquid quenching; very high surface tensile stresses



Flexible Operation: Corrosion Fatigue

- On drum units, **corrosion fatigue** has been observed on the riser tubes.
- This mechanism involves the **combination of**:
 - manufacturing-induced bend stresses,
 - water chemistry fluctuations under cycling operation
 - thermal stress cycles




Corrosion Fatigue Failures have caused injuries and deaths in power plants

Flexibility and Plant Efficiency (Heat Rate)

Heat Rate:
Energy in Fuel / Electrical Energy to Grid

- Lower is Better (Inverse of Efficiency)
 - 100% Efficiency is 3,412 Btu/kWh
 - Better Heat Rate provides:
 - Fuel Savings
 - CO₂ & Emission Reductions
- By minimizing amount of fuel burned per kWh of electricity produced
- For Existing Coal-fired Plants 10,000 is Good
 - For New Combined Cycle Plants 6,500 is Good

650 MW Conventional Coal Fired Power Plant
Impact on Heat Rate operating at Part Loads (Throttling)




Flexible Operations and Heat Rate Technical Brief 3002013992


Flexible operation impacts significantly plant's ability to operate efficiently

Flexibility and Emission Controls: SCR (NOx Control)

SCR = Selective Catalytic Reduction – Reduces NOx to Nitrogen and Water



- Ammonium Bisulfate Fouling of Catalyst Surface
 - At lower loads ABS precipitates in SCR and reduces its ability to control NOx emissions




SCR Requires Minimum Temperature to Operate and Avoid Fouling

North Carolina 2017


- Coal and Gas dispatch at higher costs than solar
- Solar assets are correlated in a geographic area
- Periods of excess generation (low or negative prices)

Spring Day (4/2/2017) –Projected 2022 Solar High Case



Generation Supply Curve - North Carolina: 2020

Capacity Technology Adjustments: Combined Cycle - 100%; Combustion Turbine - 100%; Hydraulic Turbine - 100%; Internal Combustion - 100%; Nuclear - 100%; Pump Storage - 100%; Steam Turbine - 100%; Wind Turbine - 100%; Other - 100%; Geothermal - 100%; Solar - 100%;
Capacity Status Adjustments: Announced - 100%; Early Development - 100%; Advanced Development - 100%; Under Construction - 100%;



www.snl.com

Operational Flexibility – Unit Specific

- The minimum load in 2016 at Rox 2 was 150 net MW's
- In 2017, Duke staff championed a station initiative to reduce the minimum loads on all 4 units applying EPRI R&D

Unit	Minimum Load (MW _{GROSS})	Percentage of Rated Load
1	57.3	14.0
2	103.4	15.7
3	167.1	22.4
4	270.9	36.4

- The tangible benefits to Roxboro and the fleet to reducing min load include
 - Reduced hot/warm/cold cycling impacts on equipment (unit stay on vs cycling off)
 - Eliminate the cost of oil for another start-up
 - Eliminating the cost of component lay-up
 - Spinning reserve with tremendous “up” side
 - ECC flexibility with highly variable daytime solar generation
- **Modeling shows approx. \$2.5M/year system savings from the Roxboro units min load reductions**
 - These savings result from more efficient generation (gas CC) replacing the reductions achieved

EPRI | ELECTRIC POWER RESEARCH INSTITUTE

SUCCESS STORY

DUKE ENERGY REDUCES MINIMUM LOAD, AVOIDS INCREASED CYCLING AND PROVIDES INCREASED OPERATIONAL FLEXIBILITY AND GRID STABILITY

Duke Energy applied EPRI research and a web-based tool to reduce the minimum load of a formerly baseloaded plant, thereby allowing the units to remain on line more often at the reduced loads and prevent as many unit cycles. The load reduction allowed the utility to maintain the plant as a flexible, dispatchable, efficient member of its generation fleet.

NEED FOR REDUCTION OF MINIMUM LOADS

In recent years, with the increasing load from renewables, stricter environmental regulations on coal-fired stations, and cheaper natural gas prices, the operation of coal-fired power plants has changed significantly. Baseload coal-fired power plants have now become cycling plants and are likely to be shut down during low load demands. One option being considered to keep units on line during the low demand periods is to run units at minimum loads for extended periods. These new minimum loads are being investigated to avoid the costly shutdowns and the additional wear-and-tear on plant equipment.

Turndown is almost always the better option for matching generation to reduced demand. When larger units can turn down, the benefits to the fleet as a whole are substantial by reducing the need to take other generation assets offline.

However, because most coal-fired plants were not designed for long operating periods at minimum load, reducing the minimum sustainable load on a plant is proving to be a challenge for many facilities. Reduction in load requires operating below design flow rates, temperatures, and pressures, and many units do not have procedures for such operation.

SYSTEMATIC APPROACH TO REDUCING MINIMUM LOAD

Several years ago, to address this industry issue, EPRI conducted research to develop a systematic approach to reducing a plant's minimum sustainable load. As part of this research, EPRI conducted several case studies in which the reduction of minimum load was successfully achieved. The lessons learned from these case studies were used to document a systematic approach to achieving this goal and are summarized in an EPRI report titled *Systematic Approach to Reducing Minimum Load* (3002002835).


The research showed that the critical portion of such an approach is to understand the system interactions and operating practices of each specific unit. The study developed a matrix/fault tree approach to troubleshooting and testing new minimum load operation. The matrix identifies potential roadblocks that may be encountered on various unit

“This effort shows how the innovation of highly engaged employees can help to solve real world problems. The team saw an opportunity for our Roxboro location to fill the gap and create an innovative and untapped energy profile. This effort will be a benefit to our employees and our customers.”

– JASON HAYNES
Roxboro Steam Electric Plant Manager
Duke Energy

Duke Energy's Roxboro Steam Electric Plant


Asset Integrity Risk Matrix – Minimum Load / Extended Layup

							Enterprise Risk Assessment																																																													
							<input type="radio"/> Financial ≥\$50M: <input type="radio"/> Reputational:		<input type="checkbox"/> No Assessing <input checked="" type="checkbox"/> Calculated																																																											
																																																																				
							<table border="1"> <tr> <th>Probability</th> <th>Minimal</th> <th>Moderate</th> <th>Significant</th> <th>Severe</th> <th>Critical</th> <th>Impact</th> </tr> <tr> <td>5</td> <td>Critical [$>15\%$]</td> <td></td> <td></td> <td>49</td> <td></td> <td>9</td> </tr> <tr> <td>4</td> <td>Severe [$<15\%$]</td> <td></td> <td></td> <td>13, 51, 56, 58</td> <td>42,45</td> <td></td> </tr> <tr> <td>3</td> <td>Significant [$<10\%$]</td> <td></td> <td></td> <td></td> <td>3,5,46</td> <td></td> </tr> <tr> <td>2</td> <td>Moderate [$<5\%$]</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td>Minimal [$<2\%$]</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td>Minimal</td> <td>Moderate</td> <td>Significant</td> <td>Severe</td> <td>Critical</td> <td>Impact</td> </tr> <tr> <td></td> <td></td> <td>1</td> <td>2</td> <td>3</td> <td>4</td> <td>5</td> <td></td> </tr> </table>				Probability	Minimal	Moderate	Significant	Severe	Critical	Impact	5	Critical [$>15\%$]			49		9	4	Severe [$<15\%$]			13, 51, 56, 58	42,45		3	Significant [$<10\%$]				3,5,46		2	Moderate [$<5\%$]						1	Minimal [$<2\%$]								Minimal	Moderate	Significant	Severe	Critical	Impact			1	2	3	4	5	
Probability	Minimal	Moderate	Significant	Severe	Critical	Impact																																																														
5	Critical [$>15\%$]			49		9																																																														
4	Severe [$<15\%$]			13, 51, 56, 58	42,45																																																															
3	Significant [$<10\%$]				3,5,46																																																															
2	Moderate [$<5\%$]																																																																			
1	Minimal [$<2\%$]																																																																			
		Minimal	Moderate	Significant	Severe	Critical	Impact																																																													
		1	2	3	4	5																																																														
Order	Risk ID	Risk Short Name					Probability		Impact		Total																																																									
1	9						5		5		25																																																									
2	45						4		4		16																																																									
3	42						4		4		16																																																									
4	49						5		3		15																																																									
5	5						3		4		12																																																									
6	13						4		3		12																																																									
7	46						3		4		12																																																									
8	51						4		3		12																																																									
9	56						4		3		12																																																									
10	3						3		4		12																																																									
11	58						4		3		12																																																									

Examples of Incidents – Significant Unanticipated Costs

Supercritical Coal Plant – Mission Minimum Load

- Two Supercritical Units
 - Each about 12,000+ hours at minimum load (accumulated over about 8 years)
 - Minimum load below the critical point (go into subcritical mode on flash tank)
 - Over 6 month period extensive bull nose failures experienced – failure mechanism long term overheating, also indications of some short term overheating damage
 - Contributing cause appears to be departure from nucleate boiling while operating below the critical point
 - Immediate fix, raise minimum load
 - Intermediate actions, partial nose replacement (**Several Million USD to replace**)
 - Cost excludes reliability (loss revenue) and immediate repair costs for prior tube leaks
 - 5 years earlier chemical cleans had been done on units to address heavy deposits



Significant Costs of flexible operation can be latent, not manifesting into immediate issues

150 MW Natural Circulation Subcritical Unit Minimum Load

- 1950's vintage roof fired subcritical unit. 150 MW operating at 2100 psi drum pressure – suffered extensive hydrogen damage in waterwall tubing found (discovered after rearwall tube leak developed):
 - 40 dutchman installed on furnace rear wall.
 - Most dutchman installed at elevation 514 ft.
 - Dutchman were up to 11 ft in length
- Unit Details:
 - Manufacturer minimum load is 85 MW
 - AVT-R & Caustic Treatment
 - Unit had a previous history of underdeposit corrosion tube failures; but prior to incident had no failures for 10 years
 - 3 years prior to tube leak entire rearwall had been borescoped
 - No indication of operating with condenser leaks.
 - No chemical events since last chemical cleaning (3 years prior to tube leak)



Historically limited hours at <25% Full load (just startup / shutdown periods)

2 years before failure >800 hours at <25% Full load

Year before failure >1000 hours at <25% Full load

A complete circulation model was developed: At <25% load a steam blanket developed on the rear wall tubes. This steam blanket hindered heat transfer and caused elevated heat fluxes in this area which was sufficient in creating a long term departure from nucleate boiling (DNB)

The presence of localized DNB conditions (steam film) triggers localized hydrogen damage.

Raised Minimum Load and Adjusted low load operation based on findings

Operation outside of acceptable range not immediately obvious, latent damage causes re-evaluation of capabilities


100 MW Subcritical Unit – Frequent BFP Starts

- 1960's Subcritical Drum-Type Wall-Fired (Reheat)
- Significant failure occurred:
 - Unit came on line at 22:05 hrs.
 - At 7:35 hrs. the following morning the unit was almost to full operating pressure of 1800psi
 - A loud explosion was heard outside the north wall of the control room
 - It caused the control room and annex to shake
 - And the plant to fill with steam.
 - Lead operator started to de-load unit but the boiler tripped on low drum level tripping the unit.
 - All DCS communication was lost on the control room screens, just the graphics remained
- Root cause found the damage to be Flow Accelerated Corrosion (FAC) – plant did have an FAC inspection program
- No Injuries

Low load feedwater pipe, located on the 2nd floor



The nominal diameter and the mean wall thickness were approximately 3.0 inches and 0.438 inches (Schedule 160).



Critical to understand how changing modes of operation impact on our units


Minimum Loads

- Major Failures
 - Extensive repairs (millions)
 - Extensive loss of generation
- In two cases needed to re-rate the minimum load upwards

Examples of Incidents – Significant Unanticipated Costs

~700 MW Supercritical Unit - Shutdown

- Tube failure occurred during a startup following a 4 month outage
- One section from circuit 1 from the cold reheat loop was removed after failure for analysis
 - Tube was 304 H stainless steel
 - Stress Corrosion Cracking identified
 - Extensive intergranular branching
 - Circuit compromised
- Root cause identified:
 - Salt Contamination present in Reheater
 - Inadequate Layup procedures
 - Susceptible Material (304 H)
- Plant adopting more protective layup procedures (impacts on time required to return unit to service)




Longer term unit will replace the susceptible 304 H with 347 H which is less susceptible to sensitization

Due to susceptible material in location where offline corrosion is likely need to reduce flexibility to preserve asset

Supercritical Coal Plant – Extended Shutdown

- One Supercritical Unit
 - ~8,000 hours of shutdown
 - On most extended shutdowns forced cooling was performed
 - For non-forced cooled shutdowns unit relied on vacuum 'drying' of reheater (lowers dewpoint but not capable to reduce offline relative humidity, i.e. removes some water and reduces the temperature at which moisture condenses but not low enough to prevent condensation)
 - Reheater tube leaks due to pitting, extensive damage found in the horizontal reheater sections as part of root cause on primary failure
 - Horizontal Reheater Replacement estimated at **Several Million USD**
 - Cost excludes reliability (loss revenue) and immediate repair costs



Value of Proper Lay-up is little for a baseloaded power plant – but there will be a tipping point

Layup


- Major Failures
 - Extensive repairs (millions)
 - Extensive loss of generation
- Inadequate protection due to needing to remain 'available'

700 MW Supercritical Units Minimum Load - Shutdown

- Unit 'A' and Unit 'B' LP Turbine installed in early 2000s
- Unit 'A' and 'B' are once through supercriticals (~700MW each) on oxygenated treatment with full flow powdex condensate polishers
 - During first Unit 'A' planned turbine inspection outage after LP install (~10years operation), cracking was found on more than 90% of the last stage (L-0) buckets
 - Based on these discoveries Unit 'B' was subsequently removed from service and the last stage buckets were inspected.
 - The buckets were found to have similar cracking (however it was less severe)
 - Laboratories' findings determined the cracking mechanism to be Stress Corrosion Cracking (SCC).
- Low level contamination identified as root cause combined with increased low load operation / unprotected shutdown
 - Cation Conductivity 0.13-0.16 uS/cm for days


Whenever a once through unit has a cation conductivity greater than 0.06µS/cm at the effluent of the polisher plant staff need to confirm the cause

Steam Purity Requirements Increase with lower Load Operation!



Offline Protection

- Attached are 60 kW heaters installed in LP Turbines
- Removed the duct from access door and lay the relative humidity (RH) wand inside the hood approximately 3 ft away from L-0 buckets.
- RH reading was 39% after it had been in the hood for about 7-8 minutes and was still dropping



Modes of Flexible Operation

Meeting the Challenge &
Value of Collaboration

EPRI's Mission Profile Working Group
16 Organization in Supplemental Project


Launched Summer 2015

Developed flexops.epri.com mapping issues and solutions associated with flexible operation for power plant systems and assets

Flexibility and Overall Plant Reliability

Major Damage Mechanisms during Flexible Operation


EPRI TR-109470



Mechanisms are well understood – applying cost effective solutions is the central challenge

Where EPRI is working on FlexOps

Program	Title	Flex %
63	Boiler Life and Availability Improvement Program	35%
64	Boiler and Turbine Steam and Cycle Chemistry	50%
65	Steam Turbines-Generators and Auxiliary Systems	15%
66	Fossil Fleet for Tomorrow	5%
68	Instrumentation, Controls and Automation	65%
69	Maintenance Management and Technology	50%
71	Combustion and Coal Quality Impacts	25%
75	Integrated Environmental Controls	25%
77	Continuous Emissions Monitoring	30%
79	Combined Cycle Turbomachinery	20%
87	Fossil Materials and Repair	50%
88	Combined Cycle HRSG and Balance of Plant	35%
104	Balance of Plant Equipment	30%
108	Operations Management and Technology	50%
185	Water Management Technology	10%
193	Renewable Generation	5%
194	Heat Rate Improvement	15%
PS173C	Strategic and Flexible Planning	50%
41.11.01	Flexible Operation Program	100%
49	Coal Comb. Products	10%
59	Multimedia Toxics Characterization	50%
78	CCP Use	25%




Supp. Project	Title	Flex %
1-108819	Superheater Outlet Header	25%
1-108396	Load Changes and Flexible Operation	100%
1-110953	PSET_P64_Supp Cycle Chemistry Alarms	50%
1-106718	Flash Dry Draining Sub-critical Drum	100%
1-110888	Use of SFRA to Detect Generator Rotor	100%
1-110176	TG Maintenance Intervals	50%
1-107227	PSET_T-G Torsional Vibration Monitoring	50%
1-109619	ComTest Phase 2 Supplemental	10%
1-110503	Concrete Thermal Energy Storage	100%
1-109252	RICE Interest Group	100%
1-107916	PSET_P68 Supp I4Gen	50%
1-108361	Simplified Analytical Technique for EMSA	25%
1-072390	PSET_P69 Supp Maintenance Case Studies	50%
1-110321	Approach for Sustainable Dynamic Combustion Optimization	100%
1-108442	Demo of Combustion Diagnostics & Optimizer for Emissions&Performance	75%
1-109567	Artificial Intelligence Application for Air Quality Control Systems	50%
1-109264	Unit Specific Predictive Model for Toxics Control	50%
1-108636	Portable Electrostatic Precipitator (ESP) Test Facility	50%
1-106768	Evaluation of Reduced-Load SCR Operation	100%
1-108203	Characterization of Stack Particulate Matter	100%
1-072056	Combustor Dynamics Monitoring for Improved Gas Turbine Reliability	25%
1-066745	Gas Turbine Rotor Life	25%
1-064708	Reducing Life Cycle Costs for Gas Turbine Hot Section Components	25%
1-106527	Application of Well Eng'd Weld Repairs for Grade 91 & other CSEF Steels	50%
1-070753	Optimizing Heat Recovery Steam Generator Drains	100%
1-109979	HRSG Spray Valve Detection	50%
1-107140	Mission Profile Working Group	100%
1-071860	PSET_108 Supp Operational Flexibility Implementation: Case Studies	100%
1-111161	Operational Flexibility Workshop	100%
1-072777	Flexible Operation of Hydropower Assets	100%
1-072366	PSET_P69 Supp SmartM&D	50%
1-109443	Assessment of Hydrated Lime Injection Upstream	50%
	Various One-off Supplementals applying Base Program R&D	


Selection of Base Funded Flexibility Projects 2018

Flexible Operations Handbooks - Volume Three, Steam Touched Components 3002010385	63 Base
Film Forming Product and Filming Amine Guidelines (pending should be complete Q1) – 3002013952	64 Base
Phase Transition Zone Chemistry and Filming Products 3002008132	64 Base
Filming Products and Corrosion Fatigue 3002013955	64 Base
Outage Intervals for Generators used in Flexible Operations 3002013652	65 Base
Steam Turbine Low Load Operation – 2018 Update (pending should be complete Q1) - 3002013589	65 Base
Energy Storage Database (ESD) - 3002013709	66 Base
Non-Battery Bulk Energy Storage - 3002013535	66 Base
Demonstration - Steam Temperature Control Strategies for Combined Cycle Units - 3002013414	68 Base
Process-Control Strategies for Low-Load Operation - 3002014391	68 Base
Pulverizer Performance Studies: Survey Results - 3002013002	71 Base
Studies on Coal and Natural Gas Cofiring: Simulation of Tangentially-Fired Furnace Cofiring Strategies - 3002013004	71 Base
FGD Operations Under Extended Minimum Low-Load Conditions - 3002013046	75 Base
Fuel Quality and Combustion Impacts on Emissions - 3002013044	75 Base
Advanced Combined-Cycle Plant Design and Construction - 3002011990	79/88 Base
Life Management of 9%Cr Steels: Evaluation of Metallurgical Risk Factors in Grade 91 Steel Parent Material - 3002009678	87 Base
Guideline of Forced Cooling for Flexible Operation - 3002013943	88 Base
Acoustic Emission Attenuator Monitoring Systems: Insights Gained from Three Site Applications - 3002014348	88/68 Base
Study and Report on CT Purge Credits (pending should be complete Q1) – 3002013538	88 Base
Ramp Rate Optimization Guide – 3002012797	108 Base
Flexible Operations and Heat Rate – 3002013992	194 Base


Primary Generation Plants capable of Flexible Operation



Conventional Coal Fired Power Plant



Combined Cycle Gas Turbine (CCGT) Power Plant




Hydroelectric Dam Power Plant

- U.S. Nuclear Power Plants have generally only been considered as baseload providers, however some plants have begun to enter into limited flexible operation modes

Example Relative Operating Statistics (Coal Plants)

	Load Changes	Starts	Capacity Factor
Baseload	4	1	92%
Load Following	2024	1	70%
Weekend Cycling	1646	49	51%
Daily Cycling	2178	242	41%
Extended Shutdown	1206	134	23%



Increasing Relative Cost of Generation


More Starts / Load Changes, More Wear and Tear, less Capacity Factor less Energy (less \$/MWh)

Spectrum of Flexible Operation

Operating Mode

Defining Characteristics

Increasing Relative Cost of Generation



Economic Viability

Lower Minimum Load

Fuel Changes (Lower-Cost Fuels)










Retrofits for flexibility are possible but economics can be challenging (especially for ramp rate)

Externalities significantly impacting costs / operation includes fuel prices, changing regulations

Mission Profiles Working Group - Key Issue Areas

Consensus of Subject Matter Experts (EPRI & Utility)

flexops.epri.com

Boiler and Chemistry	Combustion & Environmental Controls	Turbine - Generator	O&M and Balance of Plant
<p>Boiler feedpump/boilerfeedpumpturbine</p>  <p>Labels in diagram: Steam Drum, Second Stage Attenuator, First Stage Attenuator, Final Secondary Superheater, Reheat Superheater, Intermediate Secondary Superheater, Primary Superheater, Platen Secondary Superheater, Economizer, Main Steam Line, Downcomers, Overfire Air Purts, DRB-42 Burners, Coal Feeders, B&W Roll Wheel Pulverizers, Furnace, Air Heater, Primary Air Fan, Forced Draft Fan, Pulverizer Seal Air Fan.</p> <p>Boiler circulation at low load</p> <p>Increasing frequency response at low load</p> <p>Creep fatigue vs. design for baseload operations</p> <p>Excess air head cracking</p> <p>Flow</p> 	<p>FGD chemistry & wastewater treatment</p> <p>Fireside corrosion (coal quality, staging)</p> <p>SCR operations at low load</p> <p>Combustion issues (low load, startup emissions)</p> <p>Low load operation (temperature)</p>  <p>Labels in diagram: Dilution Air, Ammonia Storage Tank, SCR Reactor, Ammonia Evaporator, Dummy Layer, Spare Layer, Catalyst Layers, Air Pre-Heater, Boiler, Primary Air, Electrostatic Precipitator, SO₂ Reactor, Fabric Filter, Induced Draft Fan.</p>	<p>Generator issues: service life consumption, winding fatigue</p> <p>Turbine EHC layup (quality, viscosity)</p>  <p>LP turbine (chamber change)</p> <p>Determining economic turbine/generator reliability</p> <p>Boiler/turbine controls tuning at low load</p> <p>LP turbine inefficiency</p> <p>Higher</p> <p>Turbine</p> <p>Excess</p> <p>last sta</p> <p>Turbine</p> <p>Wider</p> <p>Rotor,</p> <p>LP turbine</p> <p>Thermal stresses on HP/IP turbines</p> <p>Auxiliary turbine casing warmers</p> <p>Impact of cycling on generator core integrity</p> 	<p>BFP flow stability at low loads</p> <p>Coal mill reliability</p> <p>Layup duration</p> <p>Sliding</p> <p>Fluctu</p> <p>Feedwater heater and turbine drain management</p>  

Issues by systems are impacted by the specific mode of operation in unique ways

Steam & Water Chemistry Issues in Various Operating

Operating Mode	Chemistry Issues	
Load Following	<ul style="list-style-type: none"> • Feedwater chemistry control • Dissolved oxygen in condensate • Sampling issues 	<ul style="list-style-type: none"> • Phosphate Hideout • Carryover (level control) • Corrosion Product Monitoring
Cycling (weekend off)	<ul style="list-style-type: none"> • Reheater pitting • Chemistry on startup 	<ul style="list-style-type: none"> • General Steam Path pitting • Carryover (swell)
Cycling (two-shifting)	<ul style="list-style-type: none"> • Boiler chemistry control • Carryover Issues 	<ul style="list-style-type: none"> • Feedwater chemistry control • Carbon dioxide ingress
Extended Layup	<ul style="list-style-type: none"> • Turbine Pitting (leading to Stress Corrosion Cracking or Corrosion Fatigue) • Chemistry System return to service 	<ul style="list-style-type: none"> • Oxygen pitting boiler tubing • Water Treatment Layup • Instrumentation layup
Sustained Minimum Load	<ul style="list-style-type: none"> • Increased steam path deposition • FAC in economizers / IP Evaporator • FAC in BFP recirculation lines • Steaming in Economizer (two-phase FAC) 	<ul style="list-style-type: none"> • DNB and Hydrogen Damage • High level of attemperating sprays • Sampling / Monitoring • Air-inleakage control

Cycle Chemistry Guidance for Combined Cycle/Heat Recovery Steam Generators Under Flexible Operation. 3002007938.

Efforts to address Flexibility Challenges



Overcoming the Challenge

Comprehensive Approach to Flexible Operations

- A comprehensive approach to assessing future flexible operations needs and responding to those needs in a manner that is economically and technically sustainable entails several steps:

1. Assessment of current fleet characteristics and capabilities.
2. Assessment of future levels of increased flexible operations, including assessment of transmission network capabilities to move power regionally.
3. Assessment of technical issues and potential solutions/workarounds for specific generation unit types associated with different specific flexible operations modes.
4. Incorporation of flexible operations criteria in future generation planning.
5. Development of unit-specific transition plans depending on the expected future operational mode(s) for the unit, addressing operational & maintenance strategies, staffing needs, and procedural needs.

Systematic Approaches to Test / Extend Flexibility
 Process for Optimizing Turndown Process for Optimizing Ramp Rate



Mission Profiles Working Group - Key Issue Areas
 Consensus of Subject Matter Experts (EPRI & Utility) flexops.epri.com

Boiler and Chemistry	Combustion & Environmental Controls	Turbine - Generator	O&M and Balance of Plant


Issues by systems are impacted by the specific mode of operation in unique ways.



RICE Interest Group
 New CCGT Plant Development
 Group


Coal Plant Ramp Rates

- Usually limited by:
 - Allowable stresses in thick wall components
 - Requires capital expenditure / unit redesign
 - Fuel Quality
 - Generally less costly coals are poorer quality
 - Controls (e.g. time lag between coal milling and turbine response)
 - Normal approach for improving ramp rates
 - May incorporate capital expenditures




Integrated Controls (B&W Steam 42nd Edition)

Superheater Outlet Headers



- Why Retrofit?
 - Capital cost versus maintenance cost
- Why IN740H?
 - Compared to traditional ferritic power plant steels, IN740H:
 - Can be made significantly thinner
 - Is in the time dependent regime



Using this material allows for thinner components more tolerant of thermal cycling

Energy Storage Can Reduce the Need for Flexibility


- If instead of operating flexibly, fossil plants run at full load and store energy when it makes sense:
 - Fossil plants export power when it is profitable as before
 - Fossil plants operate during low/negative pricing periods without exporting power and store it instead
 - Battery technology can be used; however, the cost of storage for batteries can be high at **\$385–490/kWh** installed today*

*LAZARD [*Levelized Cost of Storage – Version 3*](#) November 2017

Non-battery bulk energy storage can deliver lower cost options

Non-Battery Energy Storage Technologies

- Pumped Hydropower
 - Represents 95% of capacity today
- Compressed Air Energy Storage
 - Only two plants globally
- Liquid Air Energy Storage (LAES)
 - Demonstration stage
- Thermal Energy Storage (TES)
 - Pilot stage



Compressed Air Energy Storage




2-MWe LAES Demonstration (Highview Power)

Thermal energy is 4 times cheaper than batteries


Thermal Energy Storage (TES)

- By providing steam to TES when prices are low, the unit remains operational, avoiding shutdowns and ramping
- When prices increase, unit AND the TES units provide steam to the turbine-generators
- All three units generate power when needed



TES Example: Concrete Thermal Energy Storage


- Solid 'thermocline' structure used to store thermal energy
- Low-cost material **\$67/tonne**
- Modular system (12.5 m), small footprint



- Steam tubes embedded into concrete blocks – conductive heat transfer
- EPRI project is developing a field test at an operating coal power plant

Images courtesy of Bright Energy Storage Technologies


FlexOps Management



- General Awareness, Initial Endeavors
 - Tools for Managing Flexible Operation of Power Plants – Supplemental
 - flexops.epri.com
 - Annual Flexibility Conference (Inaugurated in 2018)
 - Periodic update meetings / webcasts
- Deeper level initial flexibility engagement
 - 2 day Flexibility Workshop Supplemental
- Operational Flexibility Case Studies Supplementals
 - Specific projects to extend capabilities of a current unit
- Flexibility Assessments

Vision – *The Flexible Future*

Adapting to change demands enhanced plant defense strategies that utilize systematic processes. Flexibility is complex and strategic countermeasures to protect assets undergoing the new operating regimes.



Managing fleet flexibility requires the inclusion of both quantitative and qualitative actions that drive awareness, apply best practices, encourages benchmarking and most importantly, integrates modifications and defense strategies to protect assets.


Many Flexible Operation Related Success Stories

- <http://genstrategy.epri.com/enabling-flexible-operations-of-the-generation-fleet/>

EPRI | ELECTRIC POWER RESEARCH INSTITUTE

Success Story

Research Helps TVA Increase Operational Flexibility and Turndown Potential of Base-load Plants



EPRI | ELECTRIC POWER RESEARCH INSTITUTE

Success Story

Enel Increases Operational Flexibility of Its Combined-Cycle Gas Turbines by Reducing Hot Startup Times



EPRI | ELECTRIC POWER RESEARCH INSTITUTE

SUCCESS STORY

PSEG FINDS OPTIMUM MIX OF AMINES FOR CORROSION PROTECTION OF HRSG COMPONENTS



EPRI | ELECTRIC POWER RESEARCH INSTITUTE

Success Story


Southern Company Develops Plans for Preservation of Plant Equipment during Shutdown and Layup



EPRI | ELECTRIC POWER RESEARCH INSTITUTE

Success Story

Oglethorpe Power, PSEG Power Install Ultrasonic Flow Meter Technology for Condensate Detection in HRSGs



EPRI | ELECTRIC POWER RESEARCH INSTITUTE

SUCCESS STORY

ENEL GLOBAL THERMAL GENERATION USES CREEP-FATIGUEPRO TO MONITOR BOILER LIFE

The international utility Enel employed EPRI's Creep-FatiguePro™ (CFPro) software to monitor accumulation of creep and fatigue damage at several locations in its coal-fired As Pontes Power Station in Galicia, Spain. The software helped the utility to track the level of damage occurring, to understand the direct effects on the plant of operational changes, and to plan remedial actions.

MONITORING CREEP AND FATIGUE WITH INCREASED CYCLING

Extensive cycling of coal-fired power plants due to variable generation and power market requirements results in accumulation of fatigue and creep damage at a faster rate than with baseload operation. The more rapid accumulation of damage requires earlier remedial action (e.g., repair, replacement) than would otherwise be necessary.

In Spain and Italy, coal-fired power plants are required to cycle extensively and operate relatively infrequently due to the power market and the extensive base of renewable energy that dispatches first. This cyclic (start-stop) operation can result in accumulation of fatigue damage, particularly in thick-walled components such as high-temperature headers that experience the greatest thermal transients. In addition, components exposed to high temperature and pressure experience creep damage over time.

Tracking the accumulation of fatigue and creep in these components is a critical element of an overall strategy to manage the life of boiler components.

CREEP-FATIGUEPRO




As Pontes Power Station

“The main innovation of this project was to develop and apply a new and unconventional methodology to solve a well-known problem. The demonstration carried out by EPRI at As Pontes Power Station with Creep-FatiguePro, allowed us to improve our technical management of boiler components.”

EPRI | ELECTRIC POWER RESEARCH INSTITUTE

Success Story

FirstEnergy Demonstrates Methodology for Implementing Expanded SCR Operation at Reduced Loads



FirstEnergy demonstrated a methodology for cost-effectively operating selective catalytic reduction (SCR) technology for control of nitrogen oxides (NOx) over extended periods of reduced plant load. The demonstration contributed to the validation of an EPRI methodology for better evaluating SCR operating limits and documented acceptable reduced-load SCR performance.

SCR Operation at Reduced Load

In general, operating plants at reduced load is more prevalent today than previously due to increasing levels of flexible operations. A key challenge of this trend involves its effects on environmental control equipment, including SCR systems. Currently deployed on 260 U.S. coal-fired units, SCR systems are designed to operate within a specific temperature range and usually are one of the prime factors limiting a unit's low-load capability. Low-load operation, which results in lower SCR inlet temperatures, can affect the process chemistry, which is designed to operate within a specific temperature range.

SCR systems reduce NOx emissions by injecting ammonia into the flue gas stream prior to passing through a catalyst reactor. Flue gas temperatures must be at or above a minimum operating temperature (MOT), defined by catalyst vendors to achieve required levels of NOx reduction and avoid ammonia slip, which is ammonia passing through unreacted. The temperature limit

Typical supercritical boiler and selective catalyst reduction (SCR) system

“With the need for operational flexibility in response to continued challenging market conditions, this project allowed us to successfully match

EPRI | ELECTRIC POWER RESEARCH INSTITUTE

Success Story

Three Utilities Demonstrate Promising Alternative Layup Technique

As part of an EPRI project, FirstEnergy, Louisville Gas and Electric and Kentucky Utilities (LG&E and KU), and Consumers Energy conducted a series of trials of a new film-forming amine as an alternative layup technique for protecting tubing, piping, and equipment in the water/steam cycle of power plants. The chemical treatment offers utilities a simple method for chemical layup that can be applied to provide cycle chemistry component protection with minimal capital expense.

Improving Layup Practices

U.S. fossil plants face special challenges in providing equipment protection during plant layups. An increasing number of units are experiencing short-term outages, due to age and cycling, as well as reduced or seasonal dispatch demands. At the start of layups, the duration is not always clear; short-term layups can quickly become long-term layups, with different requirements. Another issue is that layup techniques often require the capital purchase of equipment and/or additional operating/maintenance expenses.

New Alternative Techniques




Water beads on the surface of a condenser after application of the film-forming amine

“After application of the film-forming amine to the feedwater system, we measured a dramatic

The Future of Electricity

Transitioning Electricity Generation

- Understand Our Goals
 - Reduced carbon intensity?
 - Increased renewable generation?
 - Other?
- Make best use of our National Investment and future investments towards our goals
 - Optimizing use of existing flexible dispatchable generation is key when adding non-dispatchable generation




Together...Shaping the Future of Electricity

Conclusions

Advancing ***safe, reliable, affordable*** and ***environmentally responsible*** electricity for society through global collaboration, thought leadership and science & technology innovation








Clear Understanding of our Goals



Make best use of our national investment towards achieving our goals

CAISO Monthly Reports:


<http://www.caiso.com/Documents/MonthlyRenewablesPerformanceReport-Jan2019.html>

Jan. 2019	Summary	Net Load ▾	Pricing ▾	VER Curtailment ▾	Reliability Metrics
Summary					
	19.54% Jan Average Renewable Serving Load	19.54% Year to Date Average Renewable Serving Load	73.95% Max 5 min. Renewable Serving Load All-time	3.406TWh Jan Metered Renewable Generation	
	8876.7MW Jan Max Solar Production	8876.7MW Year to Date Max Solar Production	10740MW All-time Max Solar Production	12314MWh Jan Solar Energy Curtailed	
	4708MW Jan Max Wind Production	4708MW Year to Date Max Wind Production	5193MW All-time Max Wind Production	449.4MWh Jan Wind Energy Curtailed	
	15617MW/3hr Jan Max 3 Hour Net Load Ramp	 0.6751% Percent of 5-min Intervals with Negative Prices	 137.4% Jan Average Control Performance Standard (CPS1)	 12763.4MWh Jan Wind and Solar Energy Curtailed	


<https://www.bbc.com/news/business-40434392>

US Coal Fired Power Plant Fleet (EIA)

Total Supercritical Coal Installed Capacity (MW)




U.S. Installed Combined Cycle Capacity



Age and cycling (flexible operation) impacts plant reliability - US Fleet Relatively Young

Average retail price (cents/kWh)






2018 Flexibility Related Generation Supplementals

<u>Load Changes and Flexible Operations in Supercritical Boilers</u>	63
<u>Superheater Outlet Header: Validation of Fitness for Service Methodologies</u>	63
<u>Flash Dry Draining Sub-critical Drum Units</u>	64
<u>Application of Turbine Shaft Monitoring to Detect Blade Vibrations</u>	65
<u>Turbine Generator Maintenance Intervals: Industry Trends and Practice</u>	65
<u>Reciprocating Internal Combustion Engines (RICE) Interest Group</u>	66
<u>Advancing Concrete Thermal Energy Storage (TES)</u>	66
<u>Approach for Sustainable Dynamic Combustion Optimization</u>	71
<u>Evaluation of Reduced-Load SCR Operation</u>	75
<u>Optimizing Heat Recovery Steam Generator Drains (ending)</u>	88
<u>Mission Profile Working Group (ending)</u>	108
<u>Operational Flexibility Implementation: Case Studies</u>	108
<u>Flexible Operation of Hydropower Assets</u>	193
<i>Several other one-offs</i>	

Flexible Operation: Thermal Fatigue Damage

- Predominate failure mode in boiler and turbine components subjected to:
 - Frequent starts
 - Fast ramping
 - Load following
- Caused by:
 - Temperature mismatch between steam and metal surfaces
 - High amplitude stress cycles result
 - Rapid cooling caused by liquid quenching; very high surface tensile stresses



Header with Stub Tubes



Header ID Cracking Due to Thermal Fatigue






Header Fatigue Cracking



Damaged Header

Flexible Operation: Corrosion Fatigue



- On drum units, **corrosion fatigue** has been observed on the riser tubes.
- This mechanism involves **the combination of:**
 - manufacturing-induced bend stresses,
 - water chemistry fluctuations under cycling operation
 - thermal stress cycles




Corrosion Fatigue Failures have caused injuries and deaths in power plants

Flexibility and Emission Controls: SCR (NOx Control)

SCR = Selective Catalytic Reduction – Reduces NOx to Nitrogen and Water



- Ammonium Bisulfate Fouling of Catalyst Surface
 - At lower loads ABS precipitates in SCR and reduces its ability to control NOx emissions



SCR Requires Minimum Temperature to Operate and Avoid Fouling


Flexibility and Plant Efficiency (Heat Rate)

Heat Rate:

Energy in Fuel / Electrical Energy to Grid

- Lower is Better (Inverse of Efficiency)
 - 100% Efficiency is 3,412 Btu/kWh
- Better Heat Rate provides:
 - Fuel Savings
 - CO₂ & Emission ReductionsBy minimizing amount of fuel burned per kWh of electricity produced
- For Existing Coal-fired Plants 10,000 is Good
- For New Combined Cycle Plants 6,500 is Good

650 MW Conventional Coal Fired Power Plant
Impact on Heat Rate operating at Part Loads (Throttling)



Flexible Operations and Heat Rate Technical Brief 3002013992

Flexible operation impacts significantly plant's ability to operate efficiently