

NETL's Cost of Capturing CO₂ from Industrial Sources and Industrial Carbon Capture Retrofit Database

USEA Webinar

January 24, 2023



Sydney Hughes

NETL support contractor



Agenda

- Overview
- Design Assumptions
- Financial Methodology
- Results Summary
- Industrial Carbon Capture Retrofit Database
- Limitations
- CCRD Demonstration
- Discussion

Overview

- This study quantifies the performance of CO₂ capture systems and their greenfield and retrofit costs when applied at nine representative industrial sources
- Representative plant sizes and CO₂ available for capture from each industrial plant were chosen based on literature review, vendor input, and other NETL studies, where appropriate
- This study does not characterize reference industrial plants beyond the flowrate and stream characteristics of the available CO₂ stream. The production costs of each plant's product before and after retrofit are not considered

Case Class	Process	Plant Capacity	Capture Stream Description	CO ₂ Available for Capture (M tonnes CO ₂ /year)
High Purity	Ammonia	394,000 tonnes/year	Stripping vent: 23.52 psia	0.486
	Ethylene Oxide	364,500 tonnes/year	Acid gas removal CO ₂ stream: 43.5 psia	0.122
	Ethanol	50 M gal/year	Fermenter off-gas: 17.40 psia	0.143
	Natural Gas Processing	330 MMSCFD	CO ₂ vent: 23.52 psia	0.649
	Coal-to-Liquids	50,000 BPD	Acid gas removal CO ₂ streams: 160 psia, 265 psia, and 300 psia	8.74
	Gas-to-Liquids	50,000 BPD	Acid gas removal CO ₂ stream: 265 psia	1.86
Low Purity	Refinery Hydrogen	87,000 tonnes/year	Raw syngas from steam methane reforming: 399.9 psia	0.405
	Cement	1.3 M tonnes/year	Kiln Off-gas: 14.7 psia	1.21
	Steel/Iron	2.54 M tonnes/year	Coke oven power plant stack: 14.7 psia Coke oven gas/blast furnace stack: 14.7 psia	3.74 (total of both point sources)

- Retrofit costs were estimated for all cases, excluding CTL and GTL, by applying a factor to total plant cost (TPC)
 - High-purity retrofit factor: 1.01
 - Low-purity retrofit factor: 1.05
- High purity cases require compression and associated cooling water systems for intercooling/aftercooling
 - In some high purity cases, triethylene glycol dehydration is required to meet T&S quality specifications
- In addition to compression and intercooling/aftercooling systems, low purity cases require purification via amine-based CO₂ capture, which necessitates steam production for solvent regeneration, provided by a natural gas-fired boiler
 - In 2021, Shell provided quotes for two amine-based capture systems
 - CANSOLV post-combustion capture: Cement and Iron/Steel cases
 - ADIP-Ultra pre-combustion capture: Refinery Hydrogen case
 - Each system was quoted at 90 and 99 percent capture rates

Capital Cost Estimates and Scaling Methodology

- Capital costs were scaled per guidance in the latest revision of NETL's QGESS *Capital Cost Scaling Methodology: Revision 4 Report**
- Natural gas-fired boiler costs were scaled from a vendor quote provided in support of report development
- Compression costs were scaled from updated vendor quotes or from prior NETL study cases
- Inlet water knockout vessels and heat exchangers were considered as needed for feed streams with water content and/or temperature exceeding compressor inlet requirements
 - The costs for these equipment accounts were estimated using heuristic equations
- All cases include scaled costs for ancillary accounts such as a cooling water system, accessory electrical plant, instrumentation and control systems, site work, buildings and structures
 - These accounts were scaled from NETL's *Eliminating the Derate of Carbon Capture Retrofits***
- Operator labor is assumed with the addition of CO₂ capture in each facility; all other labor (maintenance, foreman, etc.) is considered available within the existing workforce in the reference plant for each case
 - High purity cases: 1 additional operator
 - Low purity cases: 2.3 additional operator, the difference between a supercritical pulverized coal power plant with and without 90% post-combustion capture, as shown in NETL's *Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity*
 - Iron/Steel case adds 4.6 additional operators, as there are two separate capture and compression systems in this case

*NETL maintains a library of Quality Guidelines for Energy Systems Studies (QGESS) that is used to guide technoeconomic analyses. The QGESS documents are referenced within the report and the CCRD tool and are publicly accessible via <https://netl.doe.gov/node/7513>

**Eliminating the Derate of Carbon Capture Retrofits is publicly accessible via <https://www.osti.gov/biblio/1510790>

***Cost and Performance Baseline for Fossil Energy Plants Volume 1: Bituminous Coal and Natural Gas to Electricity is publicly accessible via <https://netl.doe.gov/energy-analysis/details?id=e818549c-a565-4cbc-94db-442a1c2a70a9>

Calculating the Cost of CO₂ Capture in Industrial Cases

- The cost of capture, excluding T&S, is calculated using the equation below, where T&S costs would be an additive cost if included

$$\left(\frac{\$}{\text{tonne } CO_2} \right) = \frac{TOC * CCF + FOM + VOM + PF + PP}{\text{tonnes } CO_2 \text{ captured per year}}$$

- Where:
 - TOC – Total overnight costs of all equipment added to support capture application
 - CCF – Capital charge factor, based on industry-specific financial assumptions
 - FOM – Annual fixed operating & maintenance (O&M) costs
 - VOM – Annual variable O&M costs
 - PF – Purchased natural gas fuel, \$4.42/MMBtu
 - Used in the low purity cases to fuel the supplemental boiler required to raise steam for solvent regeneration heating needs
 - PP – Purchased power, \$60/MWh
 - Grid electricity is purchased in all cases to meet the auxiliary loads of all equipment added (i.e., no on-site power generation is considered)

Case-Specific Financial Parameters


- NETL developed industry-specific financial parameters for use in the study
- A sensitivity to the resulting capital charge factors (CCFs) is provided to demonstrate the effects of market volatility on the estimated COCs

Applicable Case(s)	Ammonia	Ethylene Oxide	Ethanol	NGP	CTL/GTL	Refinery Hydrogen	Cement	Iron & Steel
CCF = TASC/TOC * FCR	5.51%	4.74%	6.96%	6.05%	7.71%	4.55%	5.35%	7.53%
FCR	5.33%	4.63%	6.64%	5.82%	7.32%	4.39%	5.08%	6.90%
TASC/TOC	1.035	1.025	1.047	1.039	1.054	1.036	1.054	1.091
Debt/Equity	54/46	48/52	36/64	43/57	32/68	33/67	42/58	39/61
Levered ROE	1.50%	0.04%	4.51%	2.96%	5.54%	0.41%	1.42%	5.02%
Pre-tax WACC	3.46%	2.49%	4.74%	3.90%	5.41%	0.87%	2.99%	5.07%
Payback Period	30-year operational period							
Interest on Debt	5.15%							
Capital Expenditure Period	1 year					3 years		
Capital Distribution	1 st year – 100%					1 st year – 10% 2 nd year – 60% 3 rd year – 30 %		

FCR = fixed charge rate; TASC = total as-spent cost; TOC = total overnight cost; WACC = weighted average cost of capital; Note: All values represent real dollars.

Results Summary


Cost of CO₂ Capture



Results Summary

Cost of Capture – Increasing Capture Rate



- Shell quotes a capital uncertainty range of -25/+40 percent; as such, it is reasonable to conclude that normalized cost of capture, as well as capture system BEC, are essentially the same at 90 and 99 percent capture
 - The report results are considered Class 4 estimates as defined by AACE International*
- The plots below show capture system BEC at each capture rate and the vendor's quoted range of uncertainty as error bars



*Formerly known as The Association for the Advancement of Cost Engineering, AACE International provides cost estimate classifications in their Recommended Practice document series, accessible via <https://web.aacei.org/resources/recommended-practices>


Results Summary

Sensitivity Analyses: Purchased Power Price and Natural Gas Price




Cost Summary

COC and Approximate U.S. Supply per Industry



Results Summary

Sensitivity Analysis: Cement Plant Size Sensitivity




Industrial Carbon Capture Retrofit Database

- Publicly available spreadsheet tool to calculate high level estimates of cost of capture for a set of industrial facilities or for entire industrial sectors
- Allows for scenario analysis based on inputs and user-input assumptions
- Quickly determine cost impacts of different CO₂ capture rates, financing assumptions, utility pricing (i.e., supplemental natural gas and purchased power), etc.
- Companion tool to Cost of Capturing CO₂ from Industrial Sources, employing cost and performance assumptions developed for the report

A	B	C	D	E	F	G	
User Inputs and Constant							
Input Desired Scenarios t							
Parameter	Units	Value					
		Ammonia	Cement	Ethanol	Hydrogen	Natural Gas	
CO ₂ Capture Rate (Source 1)	Choose option	Default	Default	Default	Default	Default	Ca
	%	100%	90%	100%	99%	100%	Th
CO ₂ Capture Rate (Source 2)	Choose option	Default	N/A	N/A	N/A	N/A	Ca
	%	90%	N/A	N/A	N/A	N/A	Th
Capacity Factor	Choose Option	Default	Default	Default	Default	Default	De
	%	84%	79%	84%	87%	61%	Re
Retrofit Unit Capacity Applicability Limit	Choose Option	Default	Default	Default	Default	Default	Al
	TPD-CO ₂	0	0	0	0	0	ra
Retrofit Cost Factor	Choose Option	Default	Default	Default	Default	Default	M
		1.05	1.05	1.05	1.05	1.05	
Capital Charge Factor	Choose Option	Default	Default	Default	Default	Default	Ar
	Choose Option	30-year	30-year	30-year	30-year	30-year	co
		0.055	0.054	0.070	0.046	0.060	va
Advanced Options							
Maximum CO ₂ Capture Rate Per Train	Choose option	Default	Default	Default	Default	Default	If
	TPD	21,867	27,430	122,453	54,516	121,229	
Cost Year Basis	Choose Option	Default	Default	Default	Default	Default	Sc
	Year	2018	2018	2018	2018	2018	av
Cooling preference	Choose Option	State	State	State	State	State	St
Purchased Electricity Price	Choose Option	State	State	State	State	State	Pr
	\$/MWh	Varies by State	Varies by State	Varies by State	Varies by State	Varies by State	th
Purchased Natural Gas Price	Choose Option	State	State	N/A	State	N/A	Pr
	\$/MMBtu	Varies by State	Varies by State	N/A	Varies by State	N/A	ea
Additional Auxiliary Load Penalty	Choose Option	None	None	None	None	None	Th
	kW/TPD-CO ₂	N/A	N/A	N/A	N/A	N/A	
CO ₂ Transport and Storage Costs	Choose Option	Default	Default	Default	Default	Default	Th
	\$/tonne captured	10	10	10	10	10	Th
Include Natural Gas Boiler Emissions in Capture Feed	Choose Option	Yes	Yes	N/A	Yes	N/A	If


Industrial Carbon Capture Retrofit Database

CCRD CO₂ Supply Curve using Industrial Report Parameters




Industrial Carbon Capture Retrofit Database

Comparison of Industrial Report Cases with Plant Database Range from CCRD



Industrial Carbon Capture Retrofit Database

Cement Plants by State – Industrial Report Parameters



Source: NETL

- The results of the industrial capture report are not meant to be representative of actual CO₂ capture costs in any industry evaluated
 - For all cases, assumptions regarding the base plant have been made. Some will be less impactful to COC (i.e., water content in a stream balanced by very high concentrations of CO₂); others (e.g., CO₂ content in the cement plant flue gas, CO₂ content in the raw natural gas inlet to the natural gas processing plant) will have significant impacts on COC
 - Capital costs in the report represent an AACE Class 4 estimate; significant additional study (i.e., front-end engineering design study) is needed to reduce uncertainty to the degree necessary for project authorization/budget decisions
- The Industrial CCRD is not meant to provide actual CO₂ capture costs for any industrial plant or sector but is a valuable tool for comparative analysis between plants within an industry or for one industry versus another (i.e., comparing capture in the ammonia sector versus the cement sector)

Content Links



Report: Cost of Capturing CO₂ from Industrial Sources, 2022

<https://www.netl.doe.gov/energy-analysis/details?id=865aaad2-9252-44d9-a48a-95599b3072b4>

User Guide: Industrial CCRD, 2022

<https://www.netl.doe.gov/energy-analysis/details?id=e6179238-998a-4b5d-9585-52ff3eb9287e>

Tool: Industrial CCRD, 2022

<https://www.netl.doe.gov/energy-analysis/details?id=a9f14d58-52d3-4a06-85cc-33d5cba5c895>

Questions/ Comments

VISIT US AT: www.NETL.DOE.gov



@NETL_DOE



@NETL_DOE



@NationalEnergyTechnologyLaboratory

CONTACT:

Tim Fout, Timothy.Fout@netl.doe.gov
Eric Grol, Eric.Grol@netl.doe.gov

Sydney Hughes, Support Contractor
Sydney.Hughes@netl.doe.gov



Sydney Hughes^{1,2}: Methodology, Software, Validation, Formal Analysis, Writing – Original Draft, Writing – Review & Editing, Visualization, Supervision; **Norma Kuehn**^{1,2}: Methodology, Software, Validation, Formal Analysis, Writing – Original Draft, Writing – Review & Editing, Visualization, Supervision; **Alex Zoelle**^{1,2}: Methodology, Software, Validation, Formal Analysis, Writing – Review & Editing, Visualization, Supervision; **Mark Woods**^{1,2}: Methodology, Writing – Review & Editing, Supervision; **Sam Henry**^{1,2}: Software, Formal Analysis, Writing – Review & Editing; **Sally Homsy**^{1,2}: Formal Analysis; **Sandeep Pidaparti**^{1,2}: Formal Analysis; **Hannah Hoffman**^{1,2}: Writing – Review & Editing; **Alana Sheriff**^{1,2}: Writing – Review & Editing; **Travis Shultz**²: Conceptualization, Writing – Review & Editing, Supervision; **Tim Fout**²: Conceptualization, Methodology, Writing – Review & Editing, Supervision; **Eric Grol**²: Writing – Review & Editing; **Robert James**²: Writing – Review & Editing

¹National Energy Technology Laboratory (NETL) Support Contractor

²NETL

This report was peer reviewed by three independent peer reviewers with various affiliations and from relevant scientific disciplines to ensure that information presented is based on sound and credible science and considered technically adequate, competently performed, properly documented, and in compliance with established quality requirements. As a step beyond standard internal quality assurance and quality control procedures, the U.S. Department of Energy (DOE) Office of Fossil Energy and Carbon Management (FECM)/NETL are committed to rigorous peer review of key work products to meet the quality standards of the research community. The following individuals served on the peer review panel:

- **Richard Bohan**, Portland Cement Association
- **Michael Matuszewski**, AristoSys, LLC
- **Technical expert (anonymity requested)**

Disclaimer



This project was funded by the Department of Energy, National Energy Technology Laboratory an agency of the United States Government, through a support contract. Neither the United States Government nor any agency thereof, nor any of its employees, nor the support contractor, nor any of their employees, makes any warranty, expressor implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.